



**T-Y-LIN INTERNATIONAL**

No Exception Taken  
 Make Correction as Noted  
 Submit Specified Item  
 Revise and Resubmit as Noted  
 Rejected

Checking is for general compliance with the design concept of the project and general compliance with the information given in the contract documents only. Any notes shown is not an approval and is subject to the requirements of the plans and specifications. Any notes shown on a specific item shall not indicate the checking of an assembly of which the item is a component. Contractor is solely responsible for dimensions which shall be confirmed and correlated at the job site, fabrication processes, techniques of construction, safety precautions, and coordination of its work with that of all other trades and the satisfactory performance of its work.

Reviewed By: *[Signature]* Date: May 29, 2012

**\*\* NOTE \*\***  
THE PURPOSE OF THIS DRAWING IS TO COORDINATE GEOMETRIC CONTROL INFORMATION AND CONNECTION SPACING. THIS DWG IS SUBMITTED FOR INFORMATION ONLY & IS NOT INTENDED FOR SHOP FABRICATION. DETAIL DWGS WILL SHOW ALL WELDING AND DIMENSIONS REQ'D FOR FABRICATION.

- NOTES:**
1. MATERIAL IS M270-50W (UN).
  3. ALL HOLES SHALL BE 15/16".
  4. BOLTS SHALL BE 7/8" A325 TYPE 3 IN UNPAINTED AREAS.
  5. BOLTS SHALL BE 7/8" A325-1 GALV. IN PAINTED AREAS (SEE GNL.)

REV.	DATE	REMARKS	DMN	CHK	APVL	SHOP
1	5/29/12	ADD HANGER SUPPORT HOLES LINES 3-4 & "U1" STRUT TO TOP (EXTIR-TEC-305400)	JTB	TJB		
MATERIAL:		SURFACE PREP. & PAINT:	HOLES:		SHOP BOLTS:	
M270-50W (UN)		SEE GNL	AS NOTED		AS NOTED	
DESCRIPTION: TYPICAL CROSSFRAME LAYOUTS - SB ROADWAY						
CASCO BAY STEEL STRUCTURES, INC.						
1 WALLACE AVE.			PHONE (207) 780-6722		TENSOR	
SOUTH PORTLAND, ME 04106			FAX (207) 780-6726		STRUCTURE:	
I-91 BRIDGE 6S OVER WHITESTONE			DRAWN:		DATE:	
BROOK & WILLIAMS STREET			HL		06/24	
COUNTY OF MINDHAM			CHKD:		DATE:	
			JTB		07/08	
LOCATION: Town of Brattleboro, VT.			JOB NO.		DWG NO.	
PROJ NO. IM 091-1(SD)			479		TD201	
CUSTOMER: BECK & BELLUCCI					REV. A	