



GREEN INTERNATIONAL AFFILIATES, INC.
407R MYSTIC AVENUE, UNIT 25, MEDFORD, MA 02155
(781) 391-5757 FAX (781) 391-8889

August 3, 2006

RECEIVED

AUG 07 2006

DESIGN

Mr. Ken Upmal, P.E.
Roadway Design Project Manager
Vermont Agency of Transportation
National Life Building Drawer 33
Montpelier, VT 05633-5001

Subject: South Burlington
IM 089-3(37)
Contract No. 0284598

Dear Ken:

As requested, we have revisited the design features for the overhead sign supports and found that they are adequate for their intended use. In addition, we contacted a couple expansion bolt manufacturers and verified that the embedment proposed is indeed sufficient.

We have reviewed the enclosed shop drawings and find no exceptions. Please note however, that these plans are for the manufacture of the structural steel components only and that we would still need to review the contractor's proposed expansion bolt system and installation procedure. Additionally, although not included in the specifications, we request that a pull test be performed to verify the expansion anchor's adequacy in the existing concrete.

Should you have any questions or need any additional information, please feel free to contact me.

Very Truly Yours,
Green International Affiliates, Inc.

Ko Ishikura, P.E.
President

MAC/sase