



ABM INFO		SHOP BILL				JOB NO.	DRG. NO.		
PAGE	LINE	NO.	DESCRIPTION	FT	IN	ASSEM. MARK	SHIPPING MARK	REMARKS	WEIGHT
	1		CROSSFRAME					CE28	
	2		L4x4x3/8	6	7	018			
	2		L4x4x3/8	8	3 1/2	021			
	4		2 x 10 7/16	1	1	K4			
	1		FB 5 x 3/8	0	7	fp4			
			FIELD BOLTS						
	24		5/8 A325	0	24			w/new	

INCLUDE BOLT TYPE/GRADE
WASHER+NUT TYPE/GRADE

WHERE?

INTERMEDIATE FRAME CF28
ONE REQ'D REPAIR ID# S28 (SPAN 2, GIRDER G4-G5)

SHOP DRAWING REVIEW

REVIEWED AS REQUIRED BY THE CONSTRUCTION CONTRACT DOCUMENTS AND APPROVED, BUT ONLY FOR COMPLIANCE TO THE DESIGN INTENT OF THE WORK, AND SUBJECT TO FURTHER LIMITATIONS AND MODIFICATIONS CONTAINED IN THE CONSTRUCTION CONTRACT DOCUMENTS.

REQUESTED REVISE AND RESUBMIT FORWARDED AS CORRECTED

CORRECTIONS OR COMMENTS MADE IN THE SHOP DRAWING DURING THIS REVIEW DO NOT RELIEVE CONTRACTOR FROM COMPLIANCE WITH REQUIREMENTS OF THE SPECIFICATIONS AND CONDITIONS. THIS CHECK IS ONLY FOR REVIEW OF GENERAL CONFORMANCE WITH THE DESIGN INTENT OF THE PROJECT AND GENERAL CONFORMANCE WITH THE INFORMATION GIVEN IN THE CONTRACT DOCUMENTS. THE CONTRACTOR IS RESPONSIBLE FOR CONFIRMING AND CORRECTING ALL QUANTITIES AND DIMENSIONS, SELECTING FABRICATION PROCESSES AND TECHNIQUES OF CONSTRUCTION, CONTROLLING THE WORK WITH THAT OF ALL OTHER TRADES, AND PERFORMING HIS WORK IN A SAFE AND SATISFACTORY MANNER.

VHB Vanessa Hampton Bruffin, Inc.
Engineers, Planners, and Scientists
26 Seaboard Farm, Bedford, NH 03110
Tel: 603-882-1111 Fax: 603-882-1112

Job Number: 50699
Reviewed By: SMH
Date: 5-7-99

OUT FOR APPROVAL	4/22/99																		
OUT FOR APPROVAL																			
ISSUED TO SHOP																			
FIELD & OFFICE																			
REV.	REMARKS	DATE	DWN	CHK	APP	Q.A.	NO.	DIA.	LGT	TYPE	WASHER								
PROJECT NO. 171R 089-1(13) STATE PROJECT NO.																			
MATERIAL: A709-36 ELECTRODES: E6010 HOLES: 1/2" SHOP BOLTS:																			
SURFACE PREP. & PAINT: SSPC-SP10, SHOWING WILLIAMS																			
PRIMER: ZINC CHAD II B69W18/B69V5																			
INTERM: HEAVY DUTY EPOXY B67W301/B60V3																			
FINISH: H. SOLID POLYURETHANE B66W301/B60V30																			
DESCRIPTION: CROSSFRAME (CF28)												DRAWN BY		DATE					
JOB: I-89 NB&SB OVER												RST		4-21-99					
WHITE RIVER, VT 14# NECR												CHKD BY							
HARTFORD VT												WJB							
												APPROV BY							
												Q.A.							
CUSTOMER: WINTHROP INC																			
CASCO BAY STEEL STRUCTURES, INC.												JOB NO.		DRG. NO.					
5 INDUSTRY ROAD SOUTH PORTLAND, ME. 04106												048		8					
PHONE (207) 772-2533 FAX. (207) 772-0580												111		REV. Δ					