



CAMBER DIAGRAM

SHOP BILL

LINE NO.	SHIPPING LIST		DESCRIPTION	LENGTH		ASSEMBLY MARK	REMARKS	MTRL. SPEC.	MATERIAL APPLICATION	
	NO.	MARK		FEET	INCHES				P.O. NO.	LINE NO.
1										
2	1	2AB2	PLATE GIRDER							
3	1	2AB3	PLATE GIRDER							
4	1	2AB4	PLATE GIRDER							
5	1	2AB5	PLATE GIRDER							
6		4	PL 7/8 x 16	58	0 7/16	TFAB1	V	M270-50W	6014NH	4
7		4	PL 1 1/8 x 16	42	5 7/8	TFAB2	V	M270-50W	6014NH	3
8		4	PL 1 3/8 x 16	58	1 9/16	BFAB1	V	M270-50W	6014NH	1
9		4	PL 1 3/8 x 16	42	5 7/8	BFAB2	V	M270-50W	6014NH	3
10		4	PL 1/2 x 37	34	4 3/8	WAB1	V	M270-50W	6014NH	8
11		4	PL 1/2 x 37	66	3	WAB2	V	M270-50W	6014NH	6
12										
13		8	PL 7/8 x 7 3/4	2	7 3/4	A1	FIN-2E	M270-50W	6016NH	1
14		2	PL 7/8 x 7 3/4	3	1	D1	FIN-2E	M270-50W	6016NH	1
15		4	PL 7/8 x 7 3/4	3	1	A2	FIN-2E	M270-50W	6016NH	1
16		1	PL 7/8 x 7 3/4	3	1	C2	FIN-2E	M270-50W	6016NH	1
17		1	PL 7/8 x 7 3/4	3	1	G2	FIN-2E	M270-50W	6016NH	1
18		15	PL 1/2 x 5	3	1	E1	TF-2E	M270-50W	6016NH	4
19		5	PL 1/2 x 5	3	1	E2	TF-2E	M270-50W	6016NH	4
20		20	PL 1/2 x 5	3	1	D2	TF-2E	M270-50W	6016NH	4
21										
22										
23										
24										
25	DOMESTIC MATERIAL									

SEE HN1 FOR FABRICATION NOTES

TVGA CONSULTANTS

NO EXCEPTIONS TAKEN REJECTED
 FURNISH AS CORRECTED
 REVISE AND RESUBMIT
 ENGINEER has reviewed Shop Drawings and Samples and other data which Contractor is required to submit, only for conformance with the information given in the Contract Documents and compatibility with the design concept of the completed Project as a functioning whole as indicated in the Contract Documents. Such reviews do not extend to means, methods, techniques, sequences or procedures of construction or to safety precautions and programs incident thereto. Such reviews do not extend to any LEED certification or accreditation. Contractor is responsible for dimensions to be confirmed and correlated at the job site; for information that pertains solely to the fabrication processes or to techniques of construction and for coordination of the work of all trades.

BY: *[Signature]*
 DATE: 11/23/2009

PROJECT No: ACIM 091-1(33)
 STA. 22+69.92 TO STA. 25+28.14
 BRIDGE No. 3N (NORTHBOUND)
 TOWN OF GUILFORD

FABRICATED BY: COLFAX
 HOLES: 12 @ (UN) SHOP FASTENERS
 SHOP PAINT: NONE
 SHOP INSPECTION: _____
 GENERAL NOTES: WORK THIS SHEET w/HF2A

DATE	NO.	BY
	R1	

ORDER NO. 08-18537H22
 DETAILS OF PL GIRDER - SPAN AB
 LINES 2, 3, 4 & 5
 PROJECT I-91 OVER BROAD BROOK AND BROAD BROOK ROAD
 LOCATION WINDHAM COUNTY, VT
 CUSTOMER MEC CONSTRUCTION
CAROLINA STEEL GROUP, LLC.

MADE BY: GM
 CHECKED BY: PDC/SB
 SOUND LEADER: Precise Drafting Co. Inc.
 DATE: 09-08

SHEET HF2B