



State of Vermont  
PDD/Structures Design Section  
National Life Building - Drawer 33  
Montpelier, VT 05633-5001  
www.aot.state.vt.us

[phone] 802-828-0621  
[fax] 802-828-3566  
[ttd] 800-253-0191

Agency of Transportation

DATE: August 21, 2012

Concrete Systems, Inc.  
9 Commercial Street  
Hudson, NH 03051

Project Name: Brighton Project #: STP 034-3(21)

Structure Identification: Box Culvert Details (CSI Job # C21314)

The following Box Culvert Layout and Fabrication details for item 540.10 Precast Concrete Structure (14'-7" x 7'-0" x 60'-0" Box) for the above project have been reviewed and are being returned herewith.


All Sheets are approved

The Calculations have been reviewed and accepted as noted. The depth of the footing is stated as 3.5' in the calculations but is actually 4'-2".

You must provide notice to Jim Wild, Structural Concrete Engineer, as to the date fabrication represented by these drawings will begin. That notice must be received and acknowledged at least seven days prior to that date, as per Specification 540. Jim may be contacted by phone at (802)828-6931 or email at [jim\\_wild@state.vt.us](mailto:jim_wild@state.vt.us). Any material fabricated prior to the notification date is subject to rejection without further cause.

If you have any questions you can contact me at 802-828-0053.

Sincerely,

  
Kristin Higgins, PE  
Project Engineer

Attachments

cc: [X] Resident Engineer w/prints Doug Bumps  
[X] Concrete Engineer w/prints Jim Wild  
[X] Contractor w/prints Morrill Construction  
[X] Construction Division - letter only  
[X] Materials & Research Section (C&IA Unit) - letter only  
[X] Files (Structures)

