

SHOP DRAWING TRANSMITTAL

DATE RETURNED:	8/7/2014	DATE SENT:	7/28/2014	PAGE <u>1</u> of <u>1</u>
----------------	----------	------------	-----------	---------------------------

To/From: TEL.# CHA III WINNERS CIRCLE ALBANY, NY 12205 ATTN: R. HENDERSON	To/From: TEL.# () MARK SARGENT PROJECT MANAGER - STRUCTURES 1 NATIONAL LIFE DRIVE MONTPELIER, VT 05633-5001
---	--

CHA PROJECT No. 21113 CONTRACT No. STP FTBR (3) TITLE: TOWN OF JERICHO PEDESTRIAN BRIDGE	FOR CHA'S RECEIVED STAMP.
SHOP DRAWING DATA: (TO BE FILLED IN BY CONTRACTOR)	
TOPIC: <u>STRUCTURAL STEEL</u>	
SPECIFICATION: <u>506.50</u>	

DO NOT MIX SUBMISSIONS FROM DIFFERENT SPEC DIVISIONS ON THIS FORM. FILL OUT NEW FORM EACH TIME!

THE ABOVE NAMED CONTRACTOR HAS EVALUATED EACH ITEM IDENTIFIED IN THIS TRANSMITTAL & CERTIFIES IT TO BE IN CONFORMANCE WITH THE CONTRACT DOCUMENTS.

THIS SUBMITTAL IS NOT BEING PRESENTED AS A SUBSTITUTION

CERTIFIED BY: RYAN HENDERSON TITLE: DESIGN MANAGER DATE: 8/5/14

ID NUMBER	QUANTITY		DESCRIPTION OF ITEM(S) BEING SUBMITTED <small>(Reference specification section and/or drawing number for each item being submitted)</small>	ENGINEER'S REVIEW STATUS
	SENT	RETURN		
506.50	1	1	Structural Steel Fabrication Shop Drawings	MCN
	1	1	Welding Procedure Specifications	NR

NET = NO EXCEPTIONS TAKEN MCN = MAKE CORRECTIONS NOTED R&R = REVISE AND RESUBMIT
 REJ = REJECTED SSI = SUBMIT SPECIFIED ITEM NR = NOT REVIEWED
 *RESUBMIT REQUIRED IF REVIEW STATUS IS R&R, REJ, SSI

CONTRACTOR'S COMMENTS:	Engineer's Comments: Structural Steel Fabrication Shop Drawings: Make corrections noted on sheets marked. Welding Procedure Specifications: Not Reviewed. However, we noticed that the maximum heat input in the prequalified welding specs. are > 50 kJ/in. Section 506.04 specifies a maximum heat input no greater than 50 kJ/in for material over 3/4 in thick. Also, WPS package should be numbered consecutively.
------------------------	---

(FOR ENGINEER'S INTERNAL USE ONLY)

Forwarded To: _____	DUE BACK TO CONTRACTOR: _____
Reviewed By: <u>L JACKSON/R. HENDERSON</u>	DATE SENT: <u>7/24/2014</u>
Returned to Contractor By: <u>R. HENDERSON</u>	DATE RETURNED: <u>8/6/2014</u>

(ENTER DATE ABOVE)