

---

Springfield Park Ride (Reference 32377-2)

---

Qty	1	Accessories	PH8
-----	---	-------------	-----

**Description of Components:**

**Accessories:** (PH8), Photoelectric Cell, Twist-lock Type.

**Note:** The accessories will be shipped separately from the luminaire box.

Miscellaneous
---------------

**Description of Components:**

**Wiring:** The connection of the luminaire is done using a terminal block connector 600V, 85A for use with #2-14 AWG. wires from the primary circuit, located inside the housing. Due to the inrush current that occurs with electronic drivers, recommend using a time-delay or slow blow fuse to avoid unnecessary and unwanted fuse blowing that can occur with fast-acting fuses.

**Hardware:** All exposed screws shall be steel zinc plated with Ceramic primer-seal basecoat to reduce seizing of the parts. All seals and sealing devices are made and/or lined with EPDM and/or silicone and/or rubber.

**Finish: Textured color to be advised (Product Standard Color only):** \_\_\_\_\_ (COLTX) and in accordance with the AAMA 2603 standard. Application of polyester powder coat paint (4 mils/100 microns) with  $\pm 1$  mils/24 microns of tolerance. The Thermosetting resins provides a discoloration resistant finish in accordance with the ASTM D2244 standard, as well as luster retention in keeping with the ASTM D523 standard and humidity proof in accordance with the ASTM D2247 standard.

The surface treatment achieves a minimum of 2000 hours for salt spray resistant finish in accordance with testing performed and per ASTM B117 standard.

**Note: IMPORTANT: All missing details must be clearly specified on the return of these approval drawings. Thank you for your cooperation.**

COLOR: \_\_\_\_\_

**LED products manufacturing standard:** The electronic components sensitive to electrostatic discharge (ESD) such as light emitting diodes (LEDs) are assembled in compliance with IEC61340-5-1 and ANSI/ESD S20.20 standards so as to eliminate ESD events that could decrease the useful life of the product.

**Vibration Resistance:** The SVM meets the **ANSI C 136.31**, American National Standard for Roadway Luminaire Vibration specifications for Bridge/overpass applications. (Tested for 3G over 100 000 cycles by an independent lab)

**Web site information details:** Click on any specific information details you need: / [Installation pictures](#) / [cULus Certification](#) / [Dynadimmer specification](#) / [Warranty](#)

**Certifications and Compliance:** cULus Listed for Canada and USA. Luminaire meets DOE and MSSLC Model Specification for LED Roadway Luminaires.