



X Reviewed  
 Rejected  
 — Furnish As Corrected  
 — Revise and Resubmit

This review is only for general conformance with the design concept and the information given in the Construction Documents. Corrections or comments made on the shop drawing during the review do not relieve the Contractor from compliance with the requirements of the Plans and Specifications. Review of a specific item shall not include review of an assembly of which an item is a component. The Contractor is responsible for dimensions to be confirmed and corrected at the job site; information that pertains solely to the fabrication process or to the means, methods, techniques, sequences and procedures of construction; coordination of the Work with that of other trades and performing all Work in a safe and satisfactory manner.

Date: October 24, 2012  
 By: D. Kul  
 McFarland Johnson

VERMONT  
 Agency of Transportation  
 X Approved  
 — Rejected  
 — Furnish as Corrected  
 — Revise & Resubmit  
 Douglas E. Bonneau, P.E.  
 Structures Project Manager  
 12/10/12  
 Date

NOTE "R"  
 CONNECTIONS FOR PAINTED END DIAPHRAGMS AND PAINTED LATERALS AT ABUTMENTS 1 AND 2 SHALL USE A325 TYPE 1 GALV. FIELD BOLTS. ALL OTHER CONNECTIONS SHALL USE A325 TYPE 3 BOLTS. SEE FIELD BOLT LIST ON DRAWING E2.

NOTE:  
 FOR GENERAL NOTES SEE DRAWING G01.

REV.	DATE	REMARKS	DWN	CHK	APVL	SHOP
MATERIAL:		SURFACE PREP. & PAINT:	HOLES:		SHOP BOLTS:	
DESCRIPTION: FRAMING PLAN						
CASCO BAY STEEL STRUCTURES, INC. 1 WALLACE AVE. PHONE (207) 780-6722 SOUTH PORTLAND, ME 04106 FAX. (207) 780-6726						
STRUCTURE: VT 100 OVER LAHOILLE RIVER MORRISTOWN, VT LAHOILLE COUNTY STP F 029-1 (2) C/1			DRAWN: JTB	DATE: 08/21		
			CHKD: PCP	DATE: 08/17		
LOCATION: MORRISTOWN, VT			JOB NO.:	DWG NO.:		
PROJ NO. STP F 029-1(2)C/1			521	E1		
CUSTOMER: MINTERSET, INC.						

WORK THIS DRAWING WITH DRAWINGS E2 & E3