




MATERIAL ITEM	THICKNESS TOLERANCE
PAVEMENT COURSES (TOTAL DEPTH)	+ 1/4"
BASE COURSES (TOTAL DEPTH)	+/- 1"
SUBBASE	+/- 1"



SITE 1 TYPICAL SECTION
FLETCHER STA. 78+50.67 TO 80+89.33




SITE 2 TYPICAL SECTION
FLETCHER STA. 118+86.00 TO 120+82.33



	A	B	C
VT ROUTE 108 SOUTH APPROACH	78+50.67	78+84.00	78+90.00
VT ROUTE 108 NORTH APPROACH	80+89.33	80+56.00	80+50.00

SITE 1 SUBBASE & PAVEMENT TRANSITION DETAIL



	A	B	C
VT ROUTE 108 SOUTH APPROACH	118+86.00	119+19.33	119+39.00
VT ROUTE 108 NORTH APPROACH	120+82.33	120+49.00	120+19.00

SITE 2 SUBBASE & PAVEMENT TRANSITION DETAIL

- NOTES:
1. GEOTEXTILE TO BE PAID AS ITEM 649.31 GEOTEXTILE UNDER STONE FILL. GEOTEXTILE SHALL FULLY WRAP AROUND DRAINAGE AGGREGATE. MINIMUM OVERLAP TO BE 24 INCHES OR AS DIRECTED BY ENGINEER.
 2. DRAINAGE AGGREGATE TO BE PAID AS ITEM 900.608 - SPECIAL PROVISION (DRAINAGE AGGREGATE).
 3. GRANULAR BORROW TO BE PAID AS ITEM 203.32 GRANULAR BORROW.
 4. TOPSOIL, SEED AND MULCH TO BE APPLIED AS DIRECTED BY THE RESIDENT ENGINEER.
 5. EDGES OF NEW PAVEMENT SHALL INCLUDE A SAFETY EDGE AS SHOWN ON SHEET 351.
 6. EMULSIFIED ASPHALT, TYPE CRS-1H, SHALL BE APPLIED AS A TACK COAT ON COLD MIXED RECYCLED PAVEMENT AT A RATE OF 0.04 TO 0.06 GAL/SY. EMULSIFIED ASPHALT TYPE CRS-1H OR RS-1H SHALL BE APPLIED AS A TACK COAT BETWEEN THE 1/2" LEVELING COURSE AND THE WEARING COURSE OF SUPERPAVE BITUMINOUS CONCRETE PAVEMENT AT A RATE OF 0.025 TO 0.04 GAL/SY. BOTH APPLICATIONS WILL BE PAID UNDER ITEM 900.683 SPECIAL PROVISION (EMULSIFIED ASPHALT) (RS-1H OR CRS-1H).
 7. EXCAVATION FOR STONE SLOPE PROTECTION AND STONE KEY SHALL BE PAID AS ITEM 203.15 COMMON EXCAVATION.
 8. FOR THE PURPOSES OF QUANTITY CALCULATION IT HAS BEEN ASSUMED ITEM 900.675 SPECIAL PROVISION (COLD MIXED RECYCLED BITUMINOUS PAVEMENT, PORTLAND CEMENT) WILL REQUIRE 4% BY WEIGHT OF ITEM 415.25 EMULSIFIED ASPHALT, COLD MIX. FOR THE SAME PURPOSE IT HAS BEEN ASSUMED 2% BY WEIGHT OF PORTLAND CEMENT WILL BE REQUIRED BY MIX DESIGN.



PROJECT TYPICAL SHEET 1	PROJECT NAME: FLETCHER
	PROJECT NUMBER: STP 027-I(22)
	FILE NAME: ...\\plotfiles\11b064bdr_ttyp1.dgn PLOT DATE: 11/15/2012
	PROJECT LEADER: GAE DESIGNED BY: ISM PROJECT TYPICAL SHEET 1
	DRAWN BY: STANTEC CHECKED BY: MCF SHEET 350 OF 387