

HAYDON BOLTS, INC.
 1181 UNITY ST.
 PHILADELPHIA, PA 19124-3104

Phone: 215-537-8700
 Fax: 215-537-5569
 E-Mail: sales@haydonbolts.com

Page 1

ROTATIONAL CAPACITY TEST RESULTS

FOSTER PRECISE
 % ACCOUNTS PAYABLE DEPT
 3 FARM LANE
 GEORGETOWN, MA 01833


PO 197786
 Project
 SO No K80214
 Invoice No

| Test No | RC0000720 | Test Date | 10/31/11 | Manufacturer | Lot No |
|----------|-----------------------------|-----------|----------|------------------------|--------|
| Bolt | 7/8(9)X 2" A325-3 BOLT | | | SLSB LLC. | 517904 |
| Nut | 7/8(9) HVY HEX NUT A563-DH3 | | | UNYTITE INC. | TB841 |
| Washer | 7/8 F436 TYPE 3 WASHER | | | PRESTIGE STAMPING INC. | C3732 |
| Washer 2 | | | | | |

| Test | Actual Installation Tension | Torque FT/LB At Installation Tension | Max. Torque FT/LB At Installation | | Final Rotation Degrees | Tension At Final Rotation LBS. | Final Status | HD Galv. Avg. Thick. Or Mech. Galv. Avg. Thick. |
|--------|-----------------------------|--------------------------------------|-----------------------------------|-----|------------------------|--------------------------------|--------------|---|
| | | | Tension <= .25 | 712 | | | | |
| Test 1 | 39,876 | 497 | 712 | 242 | 53,174 | Passed | | |
| Test 2 | 39,717 | 513 | 712 | 241 | 50,289 | Passed | | |

We certify that these tests were conducted in accordance with AASHTO-M164-05 (A325) and M253-05 (A490) and the latest revision of supplementary requirements of FHA standards.

SIGN



This certificate is advisory only and is not a warranty. This material is warranted as set forth in the Manufacturer's Standard Warranty.