



BILL OF MATERIALS				
P/N	DESCRIPTION	UNIT	MINIMUM WEIGHT [LBS/FT]	COMMENTS
COMPONENTS				
301010	HDPE COATING PELLETS	LBS	0.037	
301005	GREASE PTI TYPE	LBS	0.025	
301050	.5 STRAND 270 BARE	FT	0.521	OPTION 1
301055	.5 STRAND 270 BARE US	FT	0.521	OPTION 2
MANBOM - UNCUT				
302550	.5 STRAND 270 G&PE 50MIL	FT	0.583	OPTION 1
302556	.5 STRAND 270 G&PE 50MIL US	FT	0.583	OPTION 2
FABBOM - CUT TO LENGTH				
302555	.5 STRAND 270 G&PE 50MIL CUT	PC	0.583	

NOTE:
 OPTION 1 CAN BE DOMESTIC OR FOREIGN STRAND.
 OPTION 2 MUST BE DOMESTIC STRAND.

TABLE CONTENTS AND FORMAT CHANGED; PART 302556 ADDED.

DYWIDAG POST-TENSIONING SYSTEMS		DIMENSIONS: INCH/mm mm FOR REFERENCE ONLY	Q.A.	QUALITY PLAN NUMBER: QS003020500		PART NUMBER 302550 302555 302556
0.5" GREASED & PE SHEATHED 270 KSI STRAND (50 MIL SHEATHING)			WEIGHT SBS PER/FT.	REV.	DATE	NAME
			1	08-05-07	A.W.	PB-095
			2	05-10-04	C.S.	ECRN-0102
			3	09-29-04	H.K.	
DATE: 05-30-96 DWG: G. MALECKI CHK: C.S. APP: K.S.		MATERIAL: SEE ABOVE	SCALE NTS			DRAWING NUMBER 302550
This drawing, the pertinent enclosures, descriptions, calculations etc. and their contents are the property of DYWIDAG SYSTEMS INTERNATIONAL, USA, INC. They are not allowed to be duplicated without our permission. They are also not to be shown or explained for any reason to a third party other than for reasons expressly intended by the original receiver. They have to be returned on request.		DYWIDAG-SYSTEMS INTERNATIONAL, USA, INC.				

Vermont Agency of Transportation
RECEIVED

CK'D BY VHB OK'D BY TAS

March 7, 2017

RESUBMIT NO APPROVED AS NOTED
 BY T Sumner DATE 3/9/17

SHOP DRAWING REVIEW

REVIEWED AS REQUIRED BY THE CONSTRUCTION CONTRACT DOCUMENTS AND APPROVED, BUT ONLY FOR CONFORMANCE TO THE DESIGN CONCEPT OF THE WORK, AND SUBJECT TO FURTHER LIMITATIONS AND REQUIREMENTS CONTAINED IN THE CONSTRUCTION CONTRACT DOCUMENTS.

REJECTED REVISE AND RESUBMIT FURNISH AS CORRECTED

CORRECTIONS OR COMMENTS MADE ON THE SHOP DRAWINGS DURING THIS REVIEW DO NOT RELIEVE CONTRACTOR FROM COMPLIANCE WITH REQUIREMENTS OF THE DRAWINGS AND SPECIFICATIONS. THIS CHECK IS ONLY FOR REVIEW OF GENERAL CONFORMANCE WITH THE DESIGN CONCEPT OF THE PROJECT AND GENERAL COMPLIANCE WITH THE INFORMATION GIVEN IN THE CONTRACT DOCUMENTS. THE CONTRACTOR IS RESPONSIBLE FOR: CONFIRMING AND CORRELATING ALL QUANTITIES AND DIMENSIONS; SELECTING FABRICATION PROCESSES AND TECHNIQUES OF CONSTRUCTION; COORDINATING HIS WORK WITH THAT OF ALL OTHER TRADES; AND PERFORMING HIS WORK IN A SAFE AND SATISFACTORY MANNER.

40 IDX Drive
 Building 100, Suite 200
 South Burlington, VT 05403
 802.497.6100

Job Number: BRF 025-1(42)
 Reviewed By: E.F. LAWES
 Date: MARCH 9, 2017

COLD RIVER BRIDGES, LLC

10 LANBRO LANE
 WALPOLE, NH

TEL 603-756-9300 FAX 603-756-9303

LUDLOW BRF 0251(42)

POST TENSION DETAILS	SHEET NUMBER
DATE: 11/18/16	9