



**TRANSVERSE JOINT SECTION**  
(BETWEEN PANELS)  
SCALE: 3" = 1'-0"

**LONGITUDINAL CLOSURE POUR SECTION**  
(OVER GIRDERS 2 & 4)  
SCALE: 3" = 1'-0"

**LONGITUDINAL CLOSURE POUR PLAN**  
(OVER GIRDERS 2 & 4)  
SCALE: 3" = 1'-0"

**TRANSVERSE CLOSURE POUR PLAN**  
SCALE: 3" = 1'-0"

**ALTERNATE LONGITUDINAL CLOSURE POUR SECTION**  
(OVER GIRDERS 2 & 4)

SHEET NOT USED

**NOTE**

1. ALTERNATE BLOCKOUT CONFIGURATIONS MAY BE PRESENTED TO THE ENGINEER FOR REVIEW AND APPROVAL USED AS LONG AS THE NUMBER OF SHEAR CONNECTORS PER GIRDER MEETS OR EXCEEDS THE AMOUNT SPECIFIED ON SHEET 31.
2. NOTE, TOP AND BOTTOM FORMS NOT SHOWN FOR CLARITY. THE CONTRACTOR SHALL SUBMIT FOR REVIEW AND APPROVAL, DETAILS, MATERIALS, AND METHODS FOR INSTALLING FORMS THAT PREVENT LEAKAGE AND THAT RESIST THE HYDRAULIC HEAD PRESSURES THAT RESULTS WHEN PLACING UHPC. THE HEAD PRESSURE IS EQUAL TO ONE PSI PER VERTICAL FOOT OF JOINT. CONSULT WITH THE MANUFACTURERS RECOMMENDATIONS.
3. CHIMNEYS CONSISTING OF 5 GALLON PLASTIC PAILS SHALL BE PLACED AND SPACED ALONG THE JOINTS TO ADD HYDRAULIC PRESSURE TO PURGE ANY AIR POCKETS THAT MAY FORM WHILE CASTING THE UHPC. THIS SHALL BE IN ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATIONS.

\*THE SHIM STACK DECK SUPPORT SYSTEM & TEMPORARY GROUT DAM SHOWN IS CONCEPTUAL. THE CONTRACTOR'S PROPOSED SYSTEM SHALL BE SUBMITTED TO THE ENGINEER FOR REVIEW PER SECTION 540. OF THE STANDARD SPECIFICATIONS

REV	DATE	DESCRIPTION
1	10/13/2015	SHIM STACK NOTE REVISION

PROJECT NAME:	WAITSFIELD
PROJECT NUMBER:	BRF 013-4(39)
FILE NAME:	z12b136sup.dtl's.dgn
PROJECT LEADER:	R.YOUNG
DESIGNED BY:	D.KULL
MISCELLANEOUS DECK DETAILS 1	
PLOT DATE:	10/13/2015
DRAWN BY:	S.MERKWAN
CHECKED BY:	T.KENDRICK
SHEET	27 OF 69

