



CLIP
TOP FLG.

SEE CAMBER
DIAGRAM
BRG. AREA

CLIP
BOT. FLG.

SECT. BL

ONE ~ GIRDER ~ 4G4A

- FOR GIRDER STANDARD DETAILS, SEE SH. X2.
- FOR WEB CUTTING DIAGRAM, SEE SH. C2.
- FOR FLANGE CUTTING DIAGRAMS, SEE SH. C2.
- FOR GENERAL NOTES, SEE SH. GN1.
- "BRG. AREA" INDICATES AREA THAT MUST BE FLAT TO PROVIDE A UNIFORM EVEN CONTACT WITH SOLE PLATE.

Vermont Agency of Transportation
RECEIVED
CK'D BY _____ OK'D BY Rob Young
April 4, 2016
RESUBMIT NO Approved AsNoted
BY Rob Young DATE 04/08/2016

Approved _____ X Approved As Noted
Rejected _____

This review is only for general conformance with the design concept and the information given in the Construction Documents. Corrections or comments made on the shop drawings during the review do not relieve the Contractor from compliance with the requirements of the Plans and Specifications. Review of a specific item shall not include review of an assembly of which an item is a component. The Contractor is responsible for dimensions to be confirmed and corrected at the job site; information that pertains solely to the fabrication process or to the means, methods, techniques, sequences and procedures of construction; coordination of the Work with that of other trades and performing all Work in a safe and satisfactory manner.

McFarland Johnson
Date: 4/7/2016
By: D. Kull

NO.	DATE	REMARKS	BY
REVISIONS			
		CASCO BAY STEEL STRUCTURES ONE WALLACE AVENUE PHONE: 207-780-6722 SOUTH PORTLAND, ME 04106 FAX: 207-780-6726	
STRUCTURE		VT 100 OVER MAD RIVER	
LOCATION		TOWN OF WAITSFIELD, VERMONT	
PROJECT NO.		PROJECT NO. BRF 013-4(39) BRIDGE NO. 177	
ENGINEER		MCFARLAND JOHNSON	
CUSTOMER		A.L. ST. ONGE CONTRACTOR, INC.	
ITEM		GIRDER ~ 4G4A	
SURFACE PREP.		SSPC-SP10 OPEN HOLES 1/8"	
PAINT		NONE	
APPROVAL	DRAWN	DATE	SHEET NO.
SHOP	CHECKED	DATE	4AB
			JOB NO. 651

Sheet 04B - Project: 03/14/2016 @ 09:43 (HEATHER)