



Casco Bay Steel Structures, Inc.
One Wallace Avenue
South Portland, Maine 04106
Phone: 207.780.6722 Fax: 207.780.6726

Handling and Field Touch-up

1. All steel shall be handled with care as to not damage the coating, whether in the shop, shipping or field erection
2. Coated steel shall be protected with the use of lifting softeners, padded slings or similar
3. The General Contractor is responsible for field touch-ups using the same level of quality in the field as in the shop coating process

All blast cleaning and coating operations shall be performed in accordance with this procedure

T.Y. LIN INTERNATIONAL
THE STAMPED DOCUMENTS ARE HEREBY:

APPROVED
 APPROVED AS NOTED
 REVISE AND RESUBMIT

SEE TRANSMITTAL FOR ADDITIONAL INFORMATION AS APPLICABLE.

THIS REVIEW IS FOR GENERAL CONFORMANCE WITH DESIGN CONCEPT ONLY. ANY DEVIATION FROM THE PLANS OR SPECIFICATIONS NOT CLEARLY NOTED BY THE CONTRACTOR HAS NOT BEEN REVIEWED. REVIEW BY THE ENGINEER SHALL NOT RELIEVE THE CONTRACTOR OF THE CONTRACTUAL RESPONSIBILITY FOR ANY ERRORS OR DEVIATION FROM THE CONTRACT REQUIREMENTS.

JOSH OLUND March 24, 2017
REVIEWER DATE

Vermont Agency of Transportation
RECEIVED
CK'D BY TYLin OK'D BY TYLin
March 24, 2017
RESUBMIT No Approved AsNoted
BY Kristin Higgins DATE 3/27/2017