



Vermont Agency of Transportation
RECEIVED
CK'D BY TYLin OK'D BY TYLin
February 13, 2017
RESUBMIT No Approved
BY Kristin Higgins DATE 2/15/2017

T.Y. LIN INTERNATIONAL
THE STAMPED DOCUMENTS ARE HEREBY:
X APPROVED
APPROVED AS NOTED
REVISE AND RESUBMIT
SEE TRANSMITTAL FOR ADDITIONAL INFORMATION AS APPLICABLE.
THIS REVIEW IS FOR GENERAL CONFORMANCE WITH DESIGN
CONCEPT ONLY. ANY DEVIATION FROM THE PLANS OR
SPECIFICATIONS NOT CLEARLY NOTED BY THE CONTRACTOR HAS
NOT BEEN REVIEWED. REVIEW BY THE ENGINEER SHALL NOT
RELIEVE THE CONTRACTOR OF THE CONTRACTUAL RESPONSIBILITY
FOR ANY ERRORS OR DEVIATION FROM THE CONTRACT
REQUIREMENTS.
JOSH OLUND February 15, 2017
REVIEWER DATE

ITEM #: 900.620

STRUCTURAL STEEL TO
COMPLY W/ ASTM A6
TOLERANCE UNLESS
OTHERWISE NOTED:
FRACTIONS = ± 1/16"
ANGLES = ± 1/2"
DIAMETERS = ± 1/32"

R NO.	DATE	DESCRIPTION	BY	R NO.	DATE	DESCRIPTION	BY
1	2/7/17	REVISED PER 2/3/17 DWG REVIEW	D.K.				

TRANSITION - CONCRETE PARAPET TO HIGHWAY GUIDE RAIL
PROJECT 148 CHELSEA BHF 0169(9), VT ROUTE 110, RURAL MAJOR COLLECTOR BRIDGE 9
TOWN OF CHELSEA, COUNTY OF ORANGE, VERMONT

DRAWN	D.K.	1/3/17
CHECKED	E.P.	1/3/17
APPROVED	D.L.	1/12/17
SCALE	SCHEMATIC	
DRAWING NO. R. LAFAYETTE - CHELSEA (9) - 1		

ELDERLEE, INC.
OAKS CORNERS, NEW YORK 14518
email: dlong@elderlee.com / epeek@elderlee.com
Tel: 315-789-6670 Fax: 315-789-6615

SHEET 3 OF 6