



24F-V4 SP

Grade	Slope of grain	#of Lams
Top: N1M	1:14	1
N1M	-	1
N2M	-	1
N1D	-	2
Bottom: 302-20	1:14	1

Lam splices are random

Vermont Agency of Transportation

RECEIVED

ON: July 18, 2014

and Checked for

CONFORMANCE

BY: Jennifer Fitch DATE: 07/25/2014

STEEL ASSEMBLY BY OTHERS

T.Y. LIN INTERNATIONAL

THE STAMPED DOCUMENTS ARE HEREBY:

APPROVED
 APPROVED AS NOTED
 REVISE AND RESUBMIT

SEE TRANSMITTAL FOR ADDITIONAL INFORMATION AS APPLICABLE.

THIS REVIEW IS FOR GENERAL CONFORMANCE WITH DESIGN CONCEPT ONLY. ANY DEVIATION FROM THE PLANS OR SPECIFICATIONS NOT CLEARLY NOTED BY THE CONTRACTOR HAS NOT BEEN REVIEWED. REVIEW BY THE ENGINEER SHALL NOT RELIEVE THE CONTRACTOR OF THE CONTRACTUAL RESPONSIBILITY FOR ANY ERRORS OR DEVIATION FROM THE CONTRACT REQUIREMENTS.

JOSH OLUND
REVIEWER

07/22/2014
DATE

**FOR APPROVAL
NOT FOR CONSTRUCTION**

LAMINATED TIMBER SPECIFICATION

SPECIES: SOUTHERN PINE

STRESS GRADE: 24F-1.8E

CAMBER: 1"

LAMINATIONS: STANDARD 1-3/8"

AS PER ANSI/AITC A 190.1 IN ACCORDANCE W/ AITC 117 - CERTIFIED APA

APPEARANCE GRADE: INDUSTRIAL

MOISTURE CONTENT OF LAMINATIONS: MAXIMUM 16%

ADHESIVE: COMPLYING TO AITC A 190.1 WET-USE CONFORMING TO ASTM D 2559

LAMINATION LAYUP: COMPLYING TO AITC 117 ANNEX B TABLE B1

Prod: B4

Glue Laminated Timber Diaphragm

PRINTED: 17.07.2014

HOLE TYP. U.N.O. 1 1/2" Ø

Qty: 42

Scale: 2" = 1'0"

Date: 05-02-2014

Goodfellow inc.

Project: Floating Bridge (Brookfield)
 No.: 1314-150-U // G-28107
 Customer: Wright Construction Co. Inc.

FABRICATION
 / / /

July 17 Approval #3
 June 25 Added Notes
 DATE: REVISION

Stress Grade: 24F-1.8E
 App. Grade: Industrial
 Treatment: Preservative Type II Penta Type A 0.60#
 AWPA Use Category UC4B Commodity 6F

X-section: 5" / 8 1/4"
 Length: 1'-10 1/2"
 Material: Southern Pine

By: J.R.
 Checked: M.R.

225, Goodfellow Street
 DELSON, QUEBEC, J5B 1V5
 Tel.: 450-635-6511 Fax: 450-635-8304
 www.goodfellowinc.com