



* BASED ON MAXIMUM CONTAINMENT AREA OF 350 FT² AS MEASURED PERPENDICULAR TO THE DIRECTION OF CROSS-DRAFT (SEE VENTILATION SYSTEM TABLE ON GENERAL NOTES SHEETS)

- NOTES:
1. THESE PLANS WERE PREPARED WITHOUT THE BENEFIT OF AS-BUILT BRIDGE PLANS THE CONTRACTOR SHALL MAKE ALLOWANCE FOR BRIDGE ELEMENTS AND MODIFICATIONS NOT SHOWN ON THESE PLANS
 2. THE CONTRACTOR SHALL AVOID ATTACHING/CONNECTING TO BRIDGE ELEMENTS EXHIBITING SIGNIFICANT SECTION LOSS.
 3. FOR ADDITIONAL DETAILS, SEE CONTAINMENT MISCELLANEOUS DETAILS SHEETS.
 4. CONTRACTOR TO PROVIDE LIFE LINES MEETING OSHA 1910.66 APPENDIX C AS REQUIRED.

TYPICAL SECTION
(PHASES I THRU III)
(MOBILE DUST COLLECTOR NOT SHOWN FOR CLARITY)

Vermont Agency of Transportation
RECEIVED
ON: **May 10, 2016**
and Checked for
CONFORMANCE
BY: Mark Sargent DATE: 05/13/2016

THREE (3) EXHAUST DUCT EVENLY SPACED ACROSS DECK SECTION (TYP.)
CONTAINMENT PLATFORM CONSTRUCTED W/ CHAIN LINK FENCE HAVING A 2" MESH & 9 GAUGE WIRE OR NETTING MEETING ANSI A10.11 & OSHA 1926.500 (PART 10) SECURE FENCE TO CABLE WITH 1/4" TIES OR CABLE CLIPS. SEE CHAIN LINK FENCE LAYOUT DETAIL.

SUBMITTAL REVIEW	
Review is only for general conformity to the contract drawings and specifications and shall not relieve the contractor of his entire responsibility under the contract, including among other things, dimensions to be confirmed and correlated at the job site, and information that pertains to the fabrication processes or to techniques of construction.	
<input checked="" type="checkbox"/>	NO EXCEPTIONS TAKEN
<input type="checkbox"/>	MAKE CORRECTIONS NOTED RESUBMITTAL NOT REQUIRED
<input type="checkbox"/>	AMEND AND RESUBMIT
<input type="checkbox"/>	REJECTED - SEE REMARKS
PB AMERICAS, INC.	
BY: <i>S. Bajaj</i>	DATE: <i>5/9/16</i>



REVISIONS		DESCRIPTION	DATE	BY
02/24/16	PPS			
05/05/16	PPS	GENERAL REVISION		

PAUL STEJLEN P.E. P.E. LICENSE NUMBER 107795 A2B ENGINEERING, LLC. 5406 N. HOOVER BLVD., SUITE 12 TAMPA, FL 33634		MONOKO, LLC. 1037 PENINSULA AVENUE TARPON SPRINGS, FL 34689 PHONE (727) 940-3244 FAX (727) 279-8795		DRAWN BY: BDN 11/15 CHECKED BY: PDB 11/15 DESIGNED BY: MAT 11/15 CHECKED BY: PRS 11/15	VERMONT AGENCY OF TRANSPORTATION ROAD NO: BENNINGTON COUNTY: BF BPH 116	SHEET TITLE: CONTAINMENT SECTION DETAILS (3 OF 3) PROJECT NAME: FIVE BRIDGES ON OR OVER US ROUTE 7	REF. DWG. NO. SHEET NO. C-11A
---	--	---	--	---	---	---	----------------------------------

P:\107 Stejlen, LLC\17 Bennington-Mt. Vernon\1 Containment Plans\Cad\2 Typical.dwg