
CERTIFICATE
— OF MATERIALS —

Customer: Bore Tech LLC
Address: 1569 Breezy Hill Road
City/State/Zip: St. Johnsbury, VT 05819

Date: 3/22/2017
Date Shipped: April 2017
Contract #: Highgate STP SCRIP (12) VAOT
Our Order #: TPIO15878

MATERIALS

132LF of 72" OD x .750" Nom Wall. ASTM A252 Grade 3 Spiral Weld Steel Pipe. Bare. Bev x Sq Ends.
Melted & Manufactured in The USA with Mill Test Reports (MTR's). Final Lengths TBD

Manufacturer: Domestic

CERTIFICATION

This will certify that to the best of my knowledge and belief, the above described material was produced with the following specifications:

ASTM A252 Grade 3. 45 KSI Min Yeild, 66 KSI Min Tensile
Melted & Manufactured in USA with MTR's.

Buyer Davis

Subscribed and affirmed before me
this 22nd day of March, 2017

JOAN McLAIN
Notary Public - Notary Seal
State of Missouri
Commissioned for St. Charles County
My Commission Expires: November 17, 2019
Commission Number: 11384333

Joan McLain
Notary Public



Trinity Products, LLC
1969 West Terra Lane
O'Fallon, Mo 63366