



TY-LIN INTERNATIONAL
 The stamped document is hereby:
 X Approved
 Approved as noted
 Revised and re-submit
 See transmittal for additional information as applicable.
 This drawing is for general information only and does not constitute a contract. Any deviation from the plan or specification and tolerance noted by the Contractor has not been reviewed. Review by the Engineer shall constitute the Contractor's responsibility for any errors and deviation from the contract requirements.
 Josh Olund 08/03/2016
 Reviewer Date

Note:
 • Surface of concrete construction joint shall be cleaned and free of laitance.
 • Immediately before new concrete is placed, all CJ surfaces shall be wetted and standing water removed.

CONTRACTORS VISPE:

Vermont Agency of Transportation
RECEIVED
 CK'D BY TY Lin CK'D BY JAH
 August 2, 2016
 RESUBMIT No Approved
 BY KLS in Hignok DATE 08/03/2016

PRECAST CONCRETE BOX CULVERT SHOP DRAWINGS (SDI JOB #17682)
 SUPERVISOR: E. Barendse
 DETAILER: I. ADAMS
 CHECKER: E. Barendse
 PROJECT NAME: DUXBURY
 PROJECT #: BF 013-4(47)
 LOCATION: DUXBURY, VT

INSTALLER:
 J.A. McDONALD
 585 Gilman Rd
 Lyndon Ctr, VT 05850
 07/29/16

FABRICATOR:
 193 INDUSTRIAL AVE.
 WILLISTON, VT 05495
 Ph: (802) 658-0201
 WING_FOOTINGS

SD Ireland
 PRECAST
 6_OF_12