

WEST-90, RU-3 707  
S O 10-8-59

APPARATUS

GRAND ISLAND NORTH BERT BRIDGE SPECIFICATION  
TWO CLASS 12-802 DRUM CONTROLLERS FOR 20 1/2 220  
VOLT TYPE C1 MOTOR SEC. VOLT 187 SEC. AMPS 115.  
TO HAVE DRIFT POINT & SIX POWER POINTS IN EACH  
DIRECTION.  
TO HAVE 6 AUXILIARY SWITCHES PER DEVELOPMENT ON D12  
33-A-6799.  
TO BE COMPLETE WITH CONDUIT BOX & HORIZONTAL HANDLE  
DESIGNED FOR SEPARATE MOUNTING.  
OPERATE HANDLE CLOCKWISE FOR RAISE.  
OPERATE HANDLE COUNTER CLOCKWISE FOR LOWER  
TO BE FINISHED INSIDE & OUTSIDE IN MACHINE TOOL  
GRAY LACQUER.

CC TO H. A. ZIEGLER COS  
CC TO CONTROL VAULT TO BE FILED WITH 10-8-59