



NOTES:

1. LEG LENGTH SHALL MEET THE REQUIREMENTS OF THE MECHANICAL GROUDED CONNECTION, 3'-0" LEG IS PROVIDED FOR ESTIMATING PURPOSES.
2. DURING FABRICATION OF THE PRECAST STEM A TEMPLATE SHALL BE CREATED BY THE STEM FABRICATOR TO LOCATE THE MECHANICAL GROUT CONNECTORS. THE TEMPLATE SHALL BE USED FOR FIELD PLACEMENT OF THE VERTICAL FOOTING REINFORCEMENT TO BE INCERTED INTO THE MECHANICAL GROUT CONNECTORS.
3. THE CONNECTION FROM THE PRECAST STEM TO THE FOOTING SHALL BE INCLUDED IN THE FABRICATION DRAWINGS. THE MECHANICAL GROUDED CONNECTION SHALL MEET THE REQUIREMENTS OF ASTM 1034 AND SHALL HAVE A YEILD STRENGTH OF 125% OF THE REINFORCING STEEL YIELD STRENGTH .
4. SEE GENERAL NOTES FOR ADDITIONAL FABRICATION, CONSTRUCTION,AND SEQUENCE NOTES.
5. REINFORCING FOR THE PRECAST STEM SHALL BE EPOXY COATED ACCORDING TO SUBSECTION 713.07.
6. THE NUMBER OF DOWELS TO BE DRILLED AND GROUDED WAS DETERMINED ASSUMING THE BEDROCK TO BE SMOOTH AND AT AN INCLINE OF 45 DEGREES. THE NUMBER OF DOWELS MAY BE REDUCED WITH APPROVAL OF THE PROJECT MANAGER ONCE BEDROCK IS EXPOSED AND THE ACTUAL SURFACE ROUGHNESS AND PROFILE IS DETERMINED.

NOTE:

NF = NEAR FACE
 FF = FAR FACE
 EF = EACH FACE
 ▲ = CUT TO FIT IN FIELD
 3" CLEAR, UNLESS OTHERWISE SPECIFIED ON THE PLANS.
 2' -2" BAR LAP UNLESS OTHERWISE SPECIFIED ON THE PLANS.

SCALE 1" = 1'-0"
 1 9 6 3 0 2

PROJECT NAME: CHESTER
 PROJECT NUMBER: BRF 025-1(28)

FILE NAME: 84e061/str/sub.dgn
 PROJECT LEADER: C.P.WILLIAMS
 DESIGNED BY: R.S.YOUNG
 BRIDGE 8 ABUTMENT 2 SECTIONS

PLOT DATE: 20-SEP-2010
 DRAWN BY: M.FESSEL
 CHECKED BY: R.S.YOUNG
 SHEET 36 OF 124