



- Notes:**
1. PROVIDE "V" KNOCKOUTS FOR PIPES WITH 2" MAX. CLEARANCE TO OUTSIDE OF PIPE. MORTAR ALL PIPE CONNECTIONS.
  2. JOINT SEALANT BETWEEN PRECAST SECTIONS SHALL BE PREFORMED BUTYL RUBBER.

**Special Provision (Overflow Control Structure)**  
N.T.S.

**Special Provision (Pond Liner, Geomembrane) Installation**  
N.T.S.



PROJECT NAME: BARRE CITY	PLOT DATE: 3/21/2011
PROJECT NUMBER: FEGC F 026-I(34) C/2	DRAWN BY: DMP / JAR
FILE NAME: z85b010.DDET_C2.dgn	CHECKED BY:
PROJECT LEADER: G. BAKOS	SHEET 9 OF 339
DESIGNED BY: DMP / MDS	
DRAINAGE DETAILS #2	