



PO Box 508
Barton, VT 05822
Phone: (802)525-9506
Fax: (802)525-4616
www.jpsicard.com

Submittal Data Sheet

Submittal #: 16

Submission #: 1

Date: 3/10/17

Project Name: St. Johnsbury BF 7000 (20)

Owner: State of Vermont Agency of Transportation

Division:

Contractor: J.P. Sicard Inc.

Item Number: 525.45

Supplier: Harris Rebar

Description of Item: Concrete Collar - Reinforcing Steel

Substitution: NO

Engineers Review Comments:

Submitted By: Pat Uhsmann
Title: Project Manager
Company: JP Sicard Inc

Vermont Agency of Transportation

RECEIVED

CK'D BY CLD OK'D BY WBP

March 10, 2017

RESUBMIT NO Approved
BY WPELLETIER DATE 03/15/2017

Please note that these shops are approved for the collar/collar-cap combo detailed in the Contract plans. There is no additional rebar for the "custom dimensioned MSE panel" that will be cast with the south collar.