

REVISIONS

REVISION	DATE	BY	SHEET	DESCRIPTION OF REVISION	REASON FOR REVISION	REQUESTED BY
01	2/22/17	D.B.	3	ADDED LIFTING RESTRICTION AND DUNNAGE PLAYS		CUSTOMER
01	2/22/17	D.B.	4-8	ADDED CONCRETE STRENGTH FOR STRIPPING & HANDLING TO DESIGN NOTES		CUSTOMER
02	3/28/17	D.B.	3	ADDED PIECE MARKS		CUSTOMER
02	3/28/17	D.B.	4-8	ADDED CHAMFERS TO BOTTOM LONG EDGES		CUSTOMER
02	3/28/17	D.B.	4	REVISED QUANTITY & ADJUSTED ITEM TOTALS ACCORDINGLY. ADDED NOTE AT BAR CHART FOR PROVIDING LOOSE TIGHTENING BARS.		CUSTOMER
02	3/28/17	D.B.	6,6,7,8	REVISED LENGTHS, ADJUSTED ITEM TOTALS AND WEIGHTS ACCORDINGLY		
02	3/28/17	D.B.	8	REVISED QUANTITY, ADJUSTED TOTALS ACCORDINGLY		CUSTOMER
02	3/28/17	D.B.	4-8	ADDED CURING PLAN SUBMITTED SEPARATELY TO ALL DESIGN NOTES		CUSTOMER
02	3/28/17	D.B.	7	ADDED 2ND LONGITUDINAL DIMENSION IN PLAN, CORRECTED BAR CALLOUTS IN SECTION D-D		CUSTOMER
02	3/28/17	D.B.	8	CORRECTED PIECE HIGHLIGHT IN LEGEND		CUSTOMER
02	3/28/17	D.B.	8	REVISED LENGTH OF PIECE AND ADJUSTED REINFORCING ACCORDINGLY		CUSTOMER
02	3/28/17	D.B.	1,4,10	REVISED THE LENGTH OF (1) C/W-7 TO MAKE NEW PIECE C/W-7 AND UPDATED DRAWING SCHEDULE ACCORDINGLY	TOTAL LENGTH OF PIECES IN WEST SIDE OF NORTH RETAINING WALL WAS TOO LONG	CUSTOMER
03	3/28/17	D.B.	5,8,8	CORRECTED QUANTITY OF LATERAL BAR SPACES IN REINFORCING VIEWS		CUSTOMER
04	4/4/17	D.B.	3,4	REMOVED PIECE TYPE C/W-7 AND REPLACED IT WITH C/W-1 IN NORTHWEST SECTION OF NORTH RETAINING WALL	TO ALLOW 8" OF OVERHANG AMOUNT PAST WORK POINT 4	CUSTOMER

Vermont Agency of Transportation
RECEIVED
 CK'D BY CLD OK'D BY WBP
 April 6, 2017
 RESUBMIT n0 Approved
 BY WPELLETIER DATE 04/07/2017

Outcaste Pre-cast
 1000 W. 10th Street, Suite 100
 Burlington, VT 05401
 Phone: 802-249-1111
 Fax: 802-249-1112
 www.outcasteprecast.com

STATE OF VERMONT, AGENCY OF TRANSPORTATION
 VERMONT FACILITY DESIGN (MATERIALS)

PROJECT NUMBER: _____
 DRAWING NUMBER: 200(201)
 CONTRACT NO.: 2017
 SHEET NO.: 10017
 SHEET TOTAL: 10017

DATE: _____
 DESIGNED BY: _____
 CHECKED BY: _____
 APPROVED BY: _____
 DATE: _____

2 OF 9

SHOP DRAWING REVIEW

REVIEWED AS REQUIRED BY THE CONSTRUCTION CONTRACT DOCUMENTS AND APPROVED, BUT ONLY FOR CONFORMANCE TO THE DESIGN REQUIREMENTS OF THE CONSTRUCTION CONTRACT DOCUMENTS. REQUESTS CONTAINED IN THE CONSTRUCTION CONTRACT DOCUMENTS.

REJECTED REVISE AND RESUBMIT APPROVED AS NOTED

CORRECTIONS OR COMMENTS MADE ON THE SHOP DRAWINGS DURING THIS REVIEW DO NOT RELIEVE CONTRACTOR FROM COMPLIANCE WITH REQUIREMENTS OF THE DRAWINGS AND SPECIFICATIONS. THIS CHECK IS ONLY FOR REVIEW OF GENERAL COMPLIANCE WITH THE INFORMATION GIVEN IN THE CONTRACT DOCUMENTS. THE CONTRACTOR IS RESPONSIBLE FOR CONFIRMING AND CORRELATING ALL QUANTITIES AND DIMENSIONS. SELECTING FABRICATION METHODS, MATERIALS, AND CONSTRUCTION METHODS TO BE USED IN CONFORMANCE WITH THAT OF ALL OTHER TRADES AND PERFORMING THEIR WORK IN A SAFE AND SATISFACTORY MANNER.

Job Number: 14-0116
 Reviewed by: A. GIRALDI
 Date: 4/7/17

CTD
 CTD Consulting Engineers
 100 Commercial Street
 Burlington, VT 05401
 802-249-8222