

Transportation
Land Development
Environmental
Services



Vanasse Hangen Brustlin, Inc.

Kilton Road
Six Bedford Farms, Suite 607
Bedford, New Hampshire 03110-6532
603 644-0888
FAX 603 644-2385

**FAX
Transmittal**

Deliver To: **Robert Suckert,
Resident Engineer** From: Athanasia Robinson

Company: Vermont Agency of Transportation VHB Project No.: 50929
IM DECK (36)
So. Burlington VT Br. 68
US 2 over I-89

Telephone No.: 1-(802)-658-6870 FAX No.: 1-(802) 658-6874
Original of Telecopy: Will not be sent Date and Time: October 30, 2000

Total Number of Pages (Including Transmittal Form): 2

Bob,
I received a letter from the rail subcontractor at Lafayette Co.(attached) in response to VHB's previous request for field verification of the rail layout.

In order to clarify the information needed to complete our review, I have outlined them below.
Please forward a copy of this fax transmittal to the contractor for his response.

The contractor should respond by fax/letter that the following has been performed so we can finalize our review of the rail shop drawings.

- The proposed bridge rail layout and approach rail layout has been field verified as shown on sheet 26 of the contract plans.
- The configuration of the offset block has been determined from contractor's field measurements. (OK - noted on plans)
- The post locations on the wingwalls meet the minimum requirements as shown on Detail A-Sheet 26 of 75.

Once we have received this information, we will complete our review.

Athanasia Robinson
Athanasia Robinson
Structural Engineer
VHB, Inc.

Cc: Sherward Farnsworth, PE., VTrans (Fax. No. 1-802-828-3566)
Steve Johnson, PE., VHB, Proj. Folder, Proj. File