



CLIMB HIGH, INC.

**(N)P3/VZ3A**  
 Install Remove Transfer  
 55' #2 POLE  
 2-TRI X-ARM  
 D.E.  
 125' OF 3# 477  
 PRI & 4/0 NEUT  
 125' OF 350  
 QUAD OH SEC  
 3-(SO-GMP)  
 ANCH & 7-GUYS  
 1-(SO-VZ) ANCH  
 2-NEUT D.E.

**(N)P2/VZ124**  
 Install Remove Transfer  
 50' #2 POLE  
 1-SGL X-ARM  
 100' OF 3# 477  
 PRI & 4/0 NEUT  
 1-3# XFMR BANK,  
 W/3-37# +  
 3-CO @ 120/208  
 1-SEC (SO-GMP)  
 ANCH & GUY  
 1-NEUT BKT

**(R)P5-01/VZ129**  
 Install Remove Transfer  
 35' POLE  
 70' OF 350  
 QUAD SEC

**(R)P5-01/VZ128**  
 Install Remove Transfer  
 35' POLE  
 65' OF 350  
 QUAD SEC

**(N)P1/VZ123**  
 Install Remove Transfer  
 45' #3 POLE  
 1-DBL X-ARMS  
 1-1# OH PRI  
 RISER + 1-CO  
 3-ARRS  
 230' 3# 477 PRI  
 & 4/0 NEUT  
 1-(SO-GMP)  
 ANCH & 2-GUY  
 1-(SO-VZ) ANCH  
 1-NEUT BKT

NOTE: "MAX  
 ELEV OF 37' ON  
 NEW GMP LINES"  
 .... 5' REQ'D  
 SPACE BTWN  
 VELCO & GMP ...  
 FRAME NEUT @  
 32'

**(E)P72-11/VZ127-?**  
 P1-01  
 34786

**(E)P72-11/VZ???**  
 Install Remove Transfer  
 1-UNG PRI RISER  
 + CO/ARR  
 275' OF 1# 1/0  
 UNG PRI & NEUT  
 195' OF 3" UNG  
 PRI DUCT

NOTE:  
 GMP TO DO  
 TRENCHING/BACKFILL  
 & DUCT WORK  
 REQ'D.

**(R)P1-03/VZ126**  
 Install Remove  
 1-35' POLE  
 1-AREA LIGHT  
 131' OF #6 TRI  
 SEC

PECOR AUTO SALES, INC.

CHAMPLAIN OIL COMPANY, INC.

JOB ITEM #86423

**(N)P2/VZ124**  
 102054  
 377+24 @ 57 1/2' LT

**(N)P1/VZ123**  
 102053  
 378+25 @ 56 1/2' LT

**(R)P1-03/VZ126**  
 34765

(R-131')

D  
 62  
 2786

EXIST. CODE

D  
 62  
 9136

NEW CODE

D  
 45  
 4426

U.S. ROUTE 7

SHELBURNE ROAD

**(R)P71/VZ125X**  
 34781

**(N)P65/VZ122**  
 102051  
 380+32 @ 48 1/2' RT

**(R)P71/VZ125X**  
 34781

Install Remove Trans  
 40' POLE  
 1-SGL X-ARM  
 142' OF 3# 336  
 PRI & 4/0 NEUT  
 1-50 KVA XFMR  
 + CO  
 2-SEC D.E.  
 1-NEUT BKT

FULLER, ROBER

**(R&N)P71-11 to**  
**P65-01/VZ122A**  
 34782 to 102052

MATCH TO PLAN DRAWING NO. 14, STA. 381+00

**(N)P3-11/VZ3**  
 Install Remove Transfer  
 50' #2 POLE  
 1-TRI X-ARM  
 D.E. + 3-COS @  
 100K FUSES  
 1-DBL X-ARM  
 D.E.  
 W/1# OH PRI D.E.  
 107' OF 3# 477  
 PRI & 4/0 NEUT  
 110' OF 1/0 OH  
 TRI SEC  
 1-50KVA XFMR +  
 CO  
 2-(SO-GMP)  
 ANCH & 4-GUYS  
 1-(SO-VZ) ANCH  
 1-NEUT BKT  
 1-NEUT D.E.

ROBERTS, LAWRENCE R. & ROBERTS, SHIRLEY T.

**(R)P5/VZ130S**  
 Install Remove Transfer  
 40' POLE  
 1-DBL X-ARM  
 126'-OF 3# 336  
 PRI & 4/0 NEUT.  
 126' OF 350  
 QUAD SEC  
 1-50KVA XFMR  
 CO  
 1-(SO-GMP)  
 ANCH & GUY  
 1-NEUT BKT

STONE, ROBERT L.

**(R)P5/VZ127**  
 Install Remove Transfer  
 40' POLE  
 1-DBL X-ARM  
 1-3# XFMR  
 BANK, W/3-50s  
 + 3-CO  
 142' OF 3# 336  
 PRI & 4/0 NEUT  
 126' OF #4 TRI  
 OH SEC  
 1-NEUT BKT

**(N)P3-12/VZ4**  
 102057  
 377+16 @ 48 1/2' RT

THOMAS EDWARDS & DAWN EDWARDS,  
 Trustees of the THOMAS EDWARDS  
 REVOCABLE TRUST & Trustees of the  
 DAWN EDWARDS REVOCABLE TRUST

**(E)P3-12-01**  
 Install Remove Transfer  
 15' OF #1/0 TRI  
 SEC  
 15' OF 350 MCM  
 TRI SEC

**(N)P3-12/VZ4**  
 Install Remove Transfer  
 45' #3 POLE  
 1-DBL X-ARM  
 D.E.  
 110' OH PRI D.E.  
 110' OF 3# 1/0  
 PRI & NEUT  
 1-3# XFMR  
 BANK, W/3-37#  
 + 3-CO @  
 120/208  
 1-110' SPAN  
 GUY  
 1-(SO-GMP)  
 ANCH & GUY  
 1-NEUT BKT

**(N)P3-13/VZ123-1**  
 102058  
 378+33 @ 48' RT

**(N)P3-13/VZ123-1**  
 Install Remove Transfer  
 45' #3 POLE  
 1-1# OH PRI D.E.  
 117' OF 1# 1/0  
 PRI & NEUT  
 1-15 KVA XFMR  
 + CO  
 1-(SO) ANCH &  
 GUY  
 1-NEUT D.E.

**(E)P72-01/VZ01**  
 P3-13-01  
 34786

**(R)P72/VZ127S**  
 Install Remove Transfer  
 40' POLE  
 1-DBL X-ARM  
 1-1# OH PRI D.E.  
 + CO  
 1-15-KVA XFMR  
 + CO  
 195' OF 3# 336  
 PRI & 4/0 NEUT  
 1-ANCH & GUY  
 1-NEUT BKT

RIGHI, BRUCE A.

**(N)P3-13/VZ123-1**  
 102058  
 378+33 @ 48' RT

**(N)P3-13/VZ123-1**  
 Install Remove Transfer  
 45' #3 POLE  
 1-DBL X-ARMS  
 1-1# OH PRI D.E.  
 OFF X-ARMS +  
 1-CO  
 3-ARRS  
 165' 3# 477 PRI  
 & 4/0 NEUT  
 1-(SO-GMP)  
 ANCH & 2-GUY  
 1-(SO-VZ) ANCH  
 1-NEUT BKT  
 1-NEUT DE

NOTE: "MAX  
 ELEV OF 37' ON  
 NEW GMP LINES"  
 .... 5' REQ'D  
 SPACE BTWN  
 VELCO & GMP ...  
 FRAME NEUT @  
 32'

**(R&N)P65-01/VZ122A**  
 Install Remove Transfer  
 40' #4 POLE  
 1-1# OH PRI D.E.  
 SEC. ---  
 82' OF 1# 1/0  
 PRI & NEUT  
 1-50 KVA XFMR  
 + CO  
 1-GUY  
 1-NEUT D.E.

**(N)P65/VZ122**  
 Install Remove Transfer  
 45' #3 POLE  
 1-SGL X-ARM  
 120' OF 3# 336  
 PRI & 4/0 NEUT  
 1-3# XFMR  
 BANK, W/3-10#  
 + 3-CO/ARR @  
 120/208  
 1-NEUT BKT

NOTE: SEE  
 SHEET 15 FOR  
 REMOVAL (R)P65

**(E)P3-13-01/VZ127?**  
 Install Remove Transfer  
 15' OF #4 TRI  
 SEC

SHEET 273 OF 283

**GREEN MOUNTAIN POWER CORPORATION**  
 SOUTH BURLINGTON, VERMONT

12470Y 4W 3PH FEEDER

**32G4 OVERHEAD**

SHELBURNE ROAD RECONSTRUCTION

ROUTE 7 PHASE-1 JOB ITEM # ARE-00712-86423 & 86422  
 DRAWINGS/DISTRB/ROUTE7/RECEIVED 3-4-02/A0054591101

DRAWN: LAW CHECKED: MM APPROVED: WH SCALE: 1"=20'  
 DATE: 8-07-02 DRAWING NO. PL-24\_4.13 SHEET: 13