



- STA. 351+00--356+63.5 RT : EXIST. 6" COAL TAR STEEL GAS TO BE LOWERED WHERE NECESSARY
- STA. 356+63.5--357+00 RT : EXIST. 6" X TRU STEEL GAS TO BE LOWERED WHERE NECESSARY
- STA. 353+43.5 LT--RT : EXIST. 2" X TRU STEEL GAS TO REMAIN IN PLACE
- STA. 351+00--357+00 LT : PROPOSED NEW 2" DRISCO PE GAS
- STA. 353+05.5--353+45.5 LT : EXIST. 2" X TRU STEEL GAS TO BE RETIRED IN PLACE
- STA. 353+45.5--355+71.5 LT : EXIST. 2" DRISCO PE GAS TO BE RETIRED IN PLACE
- EXIST. GAS TO BE LOWERED
- PROPOSED NEW DRISCO PE GAS
- EXIST. GAS TO BE RETIRED IN PLACE

**VERMONT GAS SYSTEMS, INC.**  
**NATURAL GAS PIPELINE**  
**PRESSURE: MEDIUM**  
**SHELBURNE RD. ROUTE 7**  
**SHELBURNE**  
 DWN. BY: ERDMAN ANTHONY  
**DATE: FEBRUARY, 1996**  
**SCALE: 1" = 20'** **SHEET: 20**

VAOT PROJ. # NH-EGC-019-4(27)  
 GAS DESIGN & ASBUILT BY M.A. OF VGS.

Shelburne NH EGC 019-4 (27)  
 Sheet 533 of 537

#2785-2783  
 GAS-TWO SERVICES  
 SEE SHEET 21

MATCH TO PLAN DRAWING NO. 19 STA. 351+00

MATCH TO PLAN DRAWING NO. 21 STA. 357+00