



① STA. 373+782.5--374+02 RT RTE. 7 : TEST STA. TO BANK OF 14-17# MAG. ANDES 10' APART. 9/2/71.  
 ② STA. 374+46--374+49 RT RTE. 7 : TIED-IN TO EXIST. 6" X TRU STEEL GAS INST. 10/69 W/6" INS. COUP. W/D-1 T.S. & EXT. W/NEW 6" X TRU STEEL GAS SOUTH ON 9/2/71. 1'6" SOUTH OF TIE-IN--2" SAVE A VALVE NIPPLE TAP PLUGGED @ MAIN--10/69. 3' SOUTH OF TIE-IN--6" STEEL LUB. PLUG VALVE--10/69.

- PROPOSED NEW GAS
- - - EXIST. GAS TO BE RETIRED
- STA. 369+00--371+65 RT : PROPOSED NEW 6" X TRU STEEL .219 W.T. GAS. WELD JOINTS.
- STA. 371+64--372+50 RT : EXIST. 6" X TRU STEEL .188 W.T. GAS TO REMAIN IN PLACE. INST. 9/2/71 W/WELD JOINTS.
- STA. 372+50--374+46 RT : EXIST. 6" X TRU STEEL .188 W.T. GAS TO BE LOWERED. INST. 9/2/71 W/WELD JOINTS UNLESS OTHERWISE STATED.
- STA. 374+46--374+57 RT : EXIST. 6" X TRU STEEL .188 W.T. GAS TO REMAIN IN PLACE. INST. 10/69 W/WELD JOINTS UNLESS OTHERWISE STATED.
- STA. 374+57--375+00 RT : EXIST. 6" X TRU STEEL .188 W.T. GAS TO BE LOWERED. INST. 10/69 W/WELD JOINTS.
- STA. 371+67.5 RT-LT-PINEHAVEN : EXIST. 2" X TRU STEEL GAS TO REMAIN IN PLACE.
- STA. 369+00--371+62 RT : EXIST. 6" X TRU STEEL .188 W.T. GAS TO BE RETIRED IN PLACE. INST. 9/2/71 W/WELD JOINTS.

**VERMONT GAS SYSTEMS, INC.**  
**NATURAL GAS PIPELINE**  
**PRESSURE: MEDIUM**  
**SHELBURNE RD. ROUTE 7**  
**SHELBURNE**  
 DWN. BY: ERDMAN ANTHONY  
**DATE: FEBRUARY, 1996**  
**SCALE: 1" = 20'** **SHEET: 23**

STA. 394+91.5--375+04 RT  
 REFER TO ① & ② ON SHEET 24

S:\DRAWING\GAS\23\23.DWG 3/19/96 11:54:55 PM