

STRUCTURAL
STEEL


75

A.B.C. Testing, Inc.

95 FIRST STREET • P.O. BOX 868 • BRIDGEWATER, MASSACHUSETTS 02324
TELEPHONE 508 - 697 - 6068 • FAX # 508 - 697 - 6154

Radiographic Shooting Sketch

Client: L.B. Foster Co., Inc.
Purchase order: 3507
Object: 1 inch PQR plate
RT date: December 4, 2009



Technique variables data

Source: X-ray
Penetrator: (2)#20
Film type: Agfa D7
Focal Film distance: 36 inches
Shim: 0

Vermont Agency of Transportation

RECEIVED

CK'D BY WDL OK'D BY JWC

11:43 am, Jul 11, 2011

RESUBMIT _____ APPROVED
BY CWC, Proj. Mgr. DATE 07/19/11