



PROFILE
 SCALE: H: 1"=20'
 V: 1"=5'

STATION EQUATION

SEWERLINE STATION 1+13 = VTRANS STATION 12+14
 SEWERLINE STATION 3+85 = VTRANS STATION 14+84

NOTES:

- CONTRACTOR SHALL PROVIDE TEMPORARY PROVISIONS TO MAINTAIN OPERATION OF THE GRAVITY SEWER UNTIL SUCH A TIME THAT THE NEW GRAVITY SEWER LINE HAS BEEN TESTED AND ACCEPTED BY THE OWNER. CONTRACTOR SHALL PROVIDE A WORK PLAN FOR REVIEW AND APPROVAL, DETAILING HOW TEMPORARY OPERATION OF THE GRAVITY SEWER WILL BE PERFORMED.
- CONTRACTOR SHALL TEST NEW PIPING AND MANHOLES PER THE SPECIFICATIONS PRIOR TO COMMISSIONING THE SEWER. ALL TESTING MUST BE WITNESSED BY A REPRESENTATIVE OF THE OWNER.
- ALL FITTINGS FOR BENDS SHALL BE MECHANICAL JOINT FITTINGS WITH RETAINER GLANDS.

BARRE TOWN
 COUNTY OF WASHINGTON

BARRE TOWN
 BR# 6100 (7)

**BRIDGE STREET
 GRAVITY SEWER
 BRIDGE CROSSING PROFILE**

DESIGNED JAR	PROJECT NO. 09092
DRAWN JEN	
CHECKED WAE	
DATE DEC. 2010	