



ABM INFO		SHOP BILL				JOB NO. 434	DRG. NO. 51		
PAGE	LINE	NO.	DESCRIPTION	FT	IN	ASSEM. MARK	SHIPPING MARK	REMARKS	WEIGHT
	7		W30x90	21	10		B1	(CVN)(FCM)	
	14		L8x4x2	2	2	K12			
	14		DO	2	2	K14			
	7		L5x3x3/8			B1	a1		
	16B		3/8" A325-GALV.	23 1/2		SHOP		W/NEW.	
	14		DO	24		DO			
	1		K130x90	21	9		B2 ^R	(CVN)(FCM)	
	1		DO	21	9		B2 ^L	(CVN)(FCM)	
	8		L5x3x3/8	2	1	K2			
	2		L5x3x3/8	8		a1			
	32		3/8" A325-GALV.	24		SHOP			
	4		DO	24		DO			
	4		W24x68	20	6		B3		
	4		DO	20	6		B3A		
	8		DO	20	6		B4		
	6A		L6x4x7/8	1	7 1/2	K3			
	22A		3/8" A325-GALV.	24		SHOP		W/NEW.	
	4		DO	24		DO			
	4		W24x68	20	6		B5		
	4		DO	20	6		B6		
	16		L6x4x7/8	1	7 1/2	K4			
	16		DO	1	7 1/2	K4 1/2		W/NEW.	
	112		3/8" A325-GALV.	23 1/2		SHOP		W/NEW.	
	4		W24x68	20	6		B7		
	4		DO	20	6		B8		
	16		L6x4x7/8	1	7 1/2	K12			
	16		DO	1	7 1/2	K12			
	112		3/8" A325-GALV.	23 1/2		SHOP		W/NEW.	
	FIELD BOLTS								
	76		1/2" A325-GALV.	36				FIELD BOLT TO CENTERPOST	
	126		3/8" A325-GALV.	24				FIELD BOLT TO TRUSS (EST.)	
	112		DO	3				BIG TRUSS (EST.)	
	112		DO	24				DO B5-B6 TO B2 1/2	
	392		DO	24				DO B3-B4-B4-B7-B8 TO B1	
	PANEL ITEM - 506.50								

OUT FOR APPROVAL	1/2	
OUT FOR APPROVAL		
ISSUED TO SHOP		
FIELD & OFFICE		

REV.	REMARKS	DATE	DWN	CHK	APP	G.A.	NO.	DIA.	LGT	TYPE	WASHER
	PROJECT NO. BHF-G400(2)										
	STATE PROJECT NO. BRIDGE NO. 5										
	MATERIAL: A325										
	ELECTRODES: -										
	HOLES: 1/8" U.N.										
	SHOP BOLTS: 3/8"										
	SURFACE PREP. & PAINT:										A325 GALV.
	BLAST CLEAN - SPIO										
	CARBOLINE #859 - ORGANIC ZINC PRIMER										
	3705 DFT.										

DESCRIPTION: FLOOR BEAMS & STRINGERS	DRAWN BY: JPF	DATE: 12-09
JOB: TH9-TAYLOR ST. - BRIDGE NO. 5	CHKD BY: CR	
MONTPELIER, VERMONT	APPROV BY: G.A.	

CUSTOMER: WINTERSET

CASCO BAY STEEL STRUCTURES, INC.

75 SPRING HILL ROAD SACO, MAINE 04072
PHONE (207) 282-7380 FAX (207) 282-1179

JOB NO. 434 DRG. NO. 51
REV. Δ

RECEIVED
CHG
JAN 27 2010
RESUBMIT APPROVED BY WJR
DATE 2/27/10