





13/16 PER RFI #001

NO EXCEPTIONS TAKEN ☒ MAKE CORRECTIONS NOTED
☐ REJECTED ☐ REVISE & RESUBMIT
☐ SUBMIT SPECIFIED ITEM

CHECKING IS ONLY FOR GENERAL CONFORMANCE WITH THE DESIGN CONCEPT OF THE PROJECT AND GENERAL COMPLIANCE WITH THE INFORMATION GIVEN IN THE CONTRACT DOCUMENTS. ANY ACTION SHOWN IS SUBJECT TO THE REQUIREMENTS OF THE PLANS AND SPECIFICATIONS. CONTRACTOR IS RESPONSIBLE FOR DIMENSIONS WHICH SHALL BE CONFIRMED AND CORRELATED AT THE JOB SITE. FABRICATION PROCESSES AND TECHNIQUES OF CONSTRUCTION, COORDINATION OF HIS WORK WITH THAT OF ALL OTHER TRADES AND THE SATISFACTORY PERFORMANCE OF HIS WORK.

CLOUGH HARBOUR & ASSOCIATES LLP
ENGINEERS, SURVEYORS, PLANNERS & LANDSCAPE ARCHITECTS

DATE 4/29/10 BY

RECEIVED
CK'D BY CHN DIV BY
APR 30 2010
RESUBMIT APPROVED As Noted
BY WPB DATE 5/4/10

SHOP BILL

JOB NO. 434 DRG. NO. S4

ABM INFO PAGE	LINE	NO.	DESCRIPTION	FT	IN	ASSEM. MARK	SHIPPING MARK	REMARKS	WEIGHT
		2	L 4 x 3 x 5/16	41	2 3/8		R4R		
		2	Do	41	2 3/8		R4L		
		2	Do	34	3 4		R5R		
		2	Do	34	3 4		R5L		
		2	[illegible]	41	2 3/8		R6R	R6-L	
		2	[illegible]	41	2 3/8		R6L	R6-R	
		2	C6 x 8.2	41	2 3/8		R7R		
		2	Do	41	2 3/8		R7L		
		4	L 4 x 3 x 5/16	41	2 3/8	KS1 1/2			
		4	Do	41	2 3/8	KS2 1/2			
		2	4 C6 x 8.2	36	2 1/2		R8R		
		2	4 Do	36	2 1/2		R8L		
		4	L 4 x 3 x 5/16	35	11 4 1/2	KS3 1/2			
		4	Do	36	4 1/2	KS4			
		2	4 C6 x 8.2	6	0 1/2		R9R	R9-L	
		2	4 Do	6	0 1/2		R9L	R9-R	
		4	L 4 x 3 x 5/16	6	1 1/2	KS5		R9	
		4	Do	6	1 1/2	KS6		R9	
		1332	3/4" A325 TC BOLTS (GALV)	2		SHOP		W/WASHER, BEVEL WASHER	
			FIELD BOLTS						
R3-R7-R8 TO TRUSS		200	3/4" A325 TC BOLTS (GALV)	2	2 1/2		FIELD	W/2 HDN WASH	1
R4-R5-R6 TO TRUSS		100	Do	1	8 1/2		Do	Do	

PAY ITEM 506.60

APPROVED: 2-23-10

REV.	REMARKS	DATE	DWN	CHK	APP	Q.A.
	OUT FOR APPROVAL	1/21/10				
	OUT FOR APPROVAL	4/19/10				
	ISSUED TO SHOP					
	FIELD & OFFICE					
2	REMOVED LT END SEE DWG S4A	4-17-10				
1	SLOT SIDE & LENGTH	4/26/10				

NO.	DIA.	LGT	TYPE	WASHER

PROJECT NO. BHF 6400(31) STATE PROJECT NO.

MATERIAL: AASHTO M270 GR 50 (ASTM A709) ELECTRODES: — HOLES: AS NOTED SHOP BOLTS: 3/4" A325-TC GALV.

SURFACE PREP. & PAINT:
BLAST CLEAN - SP10
CARBOLINE #859 ORGANIC ZINC PRIMER 3 TO 5 DFT.

DESCRIPTION: BRIDGE RAIL — DRAWN BY JFF — DATE 12-09

JOB: TH9 - TAYLOR ST. BRIDGE #5, MONTPELIER, VERMONT — CHK'D BY CR — APPROV BY — Q.A. —

CUSTOMER: WINTERSET

CASCO BAY STEEL STRUCTURES, INC.
75 SPRING HILL ROAD SACO, MAINE 04072
PHONE (207) 282-7360 FAX. (207) 282-1179

JOB NO. 434 DRG. NO. S4 REV. 1

1" = 1'-0

© 23 27 28