



NO EXCEPTIONS TAKEN TO MAKE CORRECTIONS NOTED
 REJECTED REVISE & RESUBMIT SUBMIT SPECIFIED ITEM

CHECKING IS ONLY FOR GENERAL CONFORMANCE WITH THE DESIGN CONCEPT OF THE PROJECT AND GENERAL COMPLIANCE WITH THE INFORMATION GIVEN IN THE CONTRACT DOCUMENTS. ANY ACTIONS KNOWN SUBJECT TO THE REQUIREMENTS OF THE PLANS AND SPECIFICATIONS. CONTRACTOR IS RESPONSIBLE FOR DIMENSIONS WHICH SHALL BE CONFIRMED AND CORRELATED AT THE JOB SITE. FABRICATION PROCESSES AND TECHNIQUES OF CONSTRUCTION, COORDINATION OF HIS WORK WITH THAT OF ALL OTHER TRADES AND THE SATISFACTORY PERFORMANCE OF HIS WORK.

CLASH HARRIS ASSOCIATES LLP
 ENGINEERS, SURVEYORS, PLANNERS &
 LANDSCAPE ARCHITECTS

DATE 4/13/10 BY [Signature]

ABM INFO		SHOP BILL				JOB NO.	DRG. NO.		
PAGE	LINE	NO.	DESCRIPTION	FT	IN	ASSEM. MARK	SHIPPING MARK	REMARKS	WEIGHT
	2		L4 x 3 x 3/8	41	2 3/8		R4 ^R		
	2		DO	41	2 3/8		R4 ^L		
	2		DO	34	3/4		R5 ^R		
	2		DO	34	3/4		R5 ^L		
	2		C6 x 8.2	41	2 3/8		R7 ^R		
	2		DO	41	2 3/8		R7 ^L		
	4		L4 x 3 x 3/8	41	2 3/8		K51 ^R		
	4		DO	41	2 3/8		K52 ^R		
	2		C6 x 8.2	36	2 1/2		R8 ^R		
	2		DO	36	2 1/2		R8 ^L		
	4		L4 x 3 x 3/8	35	1 1/4		K53 ^R		
	4		DO	36	1 1/4		K54 ^R		
	4		C6 x 8.2	6	0 1/2		R9 ^R	ROLL	
	4		DO	6	0 1/2		R9 ^L	ROLL	
	4		L4 x 3 x 3/8	3	1 1/2		K55	ROLL	
	4		DO	3	1 1/2		K56	ROLL	
			3303	2			SHOP	W/INT. BEVEL WASH.	
			FIELD BOLTS						
			(200)	3"	A325 FC BOLTS (GALV)	2 1/2	FIELD	W/INT. WASH.	
			100		DO (GALV)	1 3/4	DO	DO	

R3-R7-R8 TO TRUSS -
 R4-R5-R6 TO TRUSS -

F44 ITEM 506.60

Approved: 2-23-10

OUT FOR APPROVAL	1/2/10										
OUT FOR APPROVAL	4/1/10										
ISSUED TO SHOP											
FIELD & OFFICE											
REV.	REMARKS	DATE	OWN	CHK	APP	G.A.	NO.	DIA.	LGT	TYPE	WASHER
2	REMOVED ITEM SEE DWG S4A	4/1/10									
1	SLOTS SIDE SUFFICIENT	4/1/10									
PROJECT NO. BHF 6400 (31)		STATE PROJECT NO.									
MATERIAL: A325 FC		ELECTRODES: -		HOLES: A5/16 TAP		SHOP BOLTS: 5/8"					
SURFACE PREP. & PAINT:										A325 FC GALV.	
										BLAST CLEAN - SP10	
										CARBOLINE #859 ORGANIC ZINC PRIMER	
										3 TO 5 DFT.	
DESCRIPTION: BRIDGE RAIL		DRAWN BY		DATE							
JOB:		UPF		12-09							
TH 9-TAYLOR ST. BRIDGE #5		CHKD BY									
MONTPELIER, VERMONT		CR									
		APPROV BY									
		G.A.									
CUSTOMER: WINTERSET											
CASCO BAY STEEL STRUCTURES, INC.		JOB NO.		DRG. NO.							
75 SPRING HILL ROAD SACO, MAINE 04072		434		54							
PHONE (207) 282-7360 FAX (207) 282-1179		REV.									

RECEIVED
 APR 2 2010
 APPROVED BY [Signature]
 DATE 4/1/10