

**J.P. Carrara & Sons, Inc.**

2464 CASE STREET, MIDDLEBURY, VT 05753  
T (802) 388-6363 F (802) 388-9010

## Submittal Notes

**To:** Kubricky Construction Corporation **From:** Mike Davis

**Fax:** **Pages:**

**Phone:** 518-410-3858 **Date:** 6/26/17

**Re:** Merchant's Row Bridge **Attn:** P  
Rev. #1 Shop Drawings

<b>Approved</b>	
BY:	Joel Perrigo
DATE:	06/27/2017
RESUBMIT:	No
RECEIVED:	June 27, 2017
CKD BY:	
<b>STATE OF VERMONT AGENCY OF TRANSPORTATION</b>	
<small>19.1 - Merchant's Row Abutment Precast (VHB) Review</small>	

Urgent     For Review     Please Comment     Please Reply     For Your Use

### Revision #1 Submittal - J. P. Carrara & Sons' Submittal Notes

**Transmittal Notes to Accompany Merchant's Row Shop Drawing Submission:**

1. We looked at drilling into footing and found no interference w/ the shear key or reinforcing.
2. Per the Mabey manufacturer, the 25'-3" back wall length is insignificant.
3. The label for MB-FG1 is correct per JPC drawing.
4. The label for MB-FG4 is correct per JPC drawing and the designation FG3 for the sheet is correct.
5. We have added note to move reinforcing bars as necessary to avoid interference with dowel sleeves.