



- APPROACH SLAB REINFORCING NOTES**
1. ALL REINFORCING STEEL SHALL MEET THE REQUIREMENTS OF AASHTO M31M (ASTM A615M) ALL BARS SHALL BE GRADE 420 Mpa
 2. ALL REINFORCEMENT SHALL BE EPOXY COATED U.N.O.
 3. ALL BENDS SHALL CONFORM TO ACI 318M RECOMMENDED PIN DIAMETERS
 4. ALL DIMENSIONS ARE OUT TO OUT OF REINFORCEMENT (EXCEPT RADIUS OF AS290X)
 5. PROVIDE 75 mm CLEAR COVER TYPICAL U.N.O.

CALDERWOOD ENGINEERING, ETC.
 STRUCTURAL ENGINEERING • DETAILING SERVICES
 222 RIVER ROAD, RICHMOND, ME 04877 PH/FX (207)751-4601

PREPARED FOR AUSTIN CONST., INC
 BURKE - VALUE ENGINEERING
 PROJ. BRZ-1447 (16)

DATE NOV 08
BY ETC
DESIGN/DETAIL/REVIEWED
 CHECKED-REVIEWED
 REVISIONS 1 NO REVISIONS THIS SHIT
 REVISIONS 2 NO REVISIONS THIS SHIT
 REVISIONS 3 NO REVISIONS THIS SHIT
 REVISIONS 4 FIELD CHANGES

P.E. NUMBER 9098
DATE NOV 2008

BURKE
 VALUE ENGINEERED DESIGN
 APPROACH SLAB DETAILS

SHEET NUMBER
 23