



RECEIVED
 CKD BY *CWC* OKD BY *DRP*
 MAR 07 2007
 RESUBMIT _____ APPROVED _____
 BY *CWC* DATE *3/30/07*

ALL MATERIAL (EXCEPT BOLTS) TO BE ASTM: A709M-50W	
ALL WELDS TO BE MADE WITH ELECTRODES SERIES E7XX	
OPEN HOLES ARE FOR H.S. BOLTS AND ARE TO BE FREE OF BURRS AND SCALE	
BOLTS: 7/8" M164M TYPE III	OPEN HOLES: 3/4" UN PAINT: SEE GN-1
International Bridge & Iron Co. 90 Day Street Newington, CT. 06111	
VERMONT DOT SUNDERLAND BRIDGE FED. AID PROJ. NO.: BRP-0114 (2) CONTRACTOR: PETRICCA CONSTRUCTION CORP. ENGINEER: ROGER WHITCOMB	
For Approval	Revised
Issue to Shop	DETAILS
Drawn by: D.E.	Checked by: J.J./AA
Date: 02/19/07	Date: 02/19/07
Contract	Suffix
Dwg. Number	
606	X3