

Proposed Bridge Improvement Project

Woodstock - BRO 1444 (55)

Bridge #23 Over Bridgewater Brook

Concrete:

Required Strengths:

1. Mix Design - 6000 PSI
2. Striping Strength - 4500 PSI
3. Handling Strength - 4500 PSI
4. Shipping Strength - 4500 PSI
5. Placement Strength - 6000 PSI

Fabrication Tolerances:

1. Width $\pm 1/4"$
2. Height $\pm 1/4"$
3. Length $\pm 1/2"$
4. Rebar Cover 2" Min. (Unless Noted Otherwise)
5. Rebar Spacing $\pm 1"$
6. Rebar Clearance $\pm 1/4"$
7. Insert Placement $\pm 1/4"$

Design Notes:

1. Design is in accordance w/ ASTM C1433, PCI MNL135, VAOT540 & AASHTO 2010 LRFD Bridge Design Specs Fifth Edition
2. Any conflict between tolerances listed above shall result in the usage of the stricter tolerance
3. Design Live Load = AASHTO HL-93
4. Rails: TL-3
5. Materials and Manufacturing shall conform to ASTM C1433

Coating Units:

1. Water repellent; Silane shall be applied to all the exposed concrete surfaces except the under side of the rigid frame with sprayer.

Installation:

1. Sub Base for footing to be compacted and level
2. Precast footers to be installed and bolted together
3. Bearing Pad/Shim packs to be used for leveling and elevating of rigid frame within groove/pocket provided in footers
4. Bolt rigid frame units together w/ provided hardware
5. Clean granular fill used for backfill for footers and rigid frame units so water can reach weep holes if applicable
6. Fill all lifting holes, bolt pockets, footing/rigid frame grooves and seams w/ non-shrink grout

Reinforcing:

General Notes:

1. Reinforcing Steel - ASTM A615, Grade 60 (Unless Noted Otherwise)
 - a. Precast Pedestal Walls and Footings shall be Level I
 - b. Precast Frame, Wingwalls & Headwalls shall be Level II
2. Materials and Manufacturing shall conform to ASTM C1433
3. Bar Spacing 12" or Greater Tied at Every Intersection

Tolerances:

1. Spacing $\pm 1"$
2. Clearance $\pm 1/4"$

Lap Lengths:

1. Per AASHTO 5.11.2.1.1 & 5.11.5.3.1
 - Lap Length for Level I (Plain):
 - #4 Bar=12" #6 Bar=23"
 - #5 Bar=17" #7 Bar=31"
 - #8 Bar=41"
 - Lap Lengths for Level II:
 - #4 Bar=17" #6 Bar=39"
 - #5 Bar=27" #7 Bar=53"
 - #8 Bar=69"

Joint Treatment:

Vertical Seams:

Per VTrans Approved Product List 780.02
Overhead & Vertical Concrete Repair Mortar

Horizontal Seams / Grout:

Per VTrans Approved Product List 707.03
Mortar, Type IV

Waterproofing:

1. Membrane waterproofing will be specified by the Bridge Preservation Company in a separate attachment.
2. Silane 40 shall be applied on all exposed concrete surfaces.

Miscellaneous:

1. All exposed hardware to be galvanized.
2. All Exposed Threaded Bar, Couplers & Hardware for dead men is to be Galvanized and Coated After Install w/ Bituminous Coating
3. All bolts & threaded rods to be ASTM F1554 Grade 105 Unless Noted Otherwise
4. Guardrail spacing has been coordinated with these shop drawings. Any interference in the field is to be adjusted as needed in the field

5. All Exposed Edges of Concrete Shall be Chamfered 1"x1"

Legend:

- (A) Starcon 20T-19³/₄" Lift Anchor
- (B) Mechanical Bolt Pocket (A.L. Patterson w/ 1"Ø Galv. Rod)
- (C) Oxford A750-7 Lifting Device
- (D) 1¹/₂"x3¹/₂" Continuous Keyway
- (E) 5/8" Zinc Insert (P.A. Insert Corp.)
- (F) Solid Lines Indicate 1" Chamfered Edge (Isometrics)
- (G) 1¹/₄" Galvanized Threaded Insert (Meadow Burke CX-51) 7¹/₂" Long
- (H) 8"x8"x3" Pocket w/ 2" Ø PVC Sleeve
- (I) 1¹/₂"x5¹/₂" Continuous Keyway

LRFR Load Rating Factors:

Loading Levels	Truck						
	H-20	HL-93	3S2	6 Axle	3A Str.	4A Str.	5A Semi
Tonnage	20	36	36	66	30	34.5	38
Inventory	29.0	41.8	54.4	96.4	49.2	68.3	71.4
Posting							
Operating	37.6	54.4	70.2	125.4	63.9	88.7	92.3

CONTRACTORS VTSPE:



Vermont Agency of Transportation

RECEIVED

CK'D BY RMK OK'D BY _____

June 25, 2013

RESUBMIT NO Approved
BY JTS DATE 6-26-2013

PRECAST CONCRETE RIGID FRAME SHOP DRAWINGS (SDI JOB# 13429)

SUPERVISOR: M. WHEELER
DETAILER: C. DUPLANTIS
CHECKER: M. WHEELER
ENGINEER: ENGINEERING VENTURES

PROJECT NAME: WOODSTOCK
PROJECT #: BRO 1444 (55)
LOCATION: WOODSTOCK, VT
BRIDGE: #23 ON TOWN HWY 6

CONTRACTOR:
B.U.R. CONSTRUCTION
CLAREMONT, NH 03743
Ph: (603) 542-2801

FABRICATOR:
193 INDUSTRIAL AVE.
WILLISTON, VT 05495
Ph: (802) 658-0201



05/30/13

PRECAST NOTES, SPECIFICATIONS AND LEGEND

1 OF 6