



**CAMBER DIAGRAM FOR 1S1A THRU 6S6A**

MARK	C1	C2	C3
1S1A	2 9/16	3 9/16	2 9/16
1S2A	2 5/16	3 1/4	2 5/16
2S3A	2 5/16	3 1/4	2 5/16
2S4A	2 5/16	3 1/4	2 5/16
3S5A	2 5/16	3 1/4	2 5/16
3S6A	2 3/8	3 5/16	2 3/8

- Reviewed
- Rejected
- Furnish as Complied
- Revise and Resubmit
- Submit Specified Item

This review is only for general conformance with the design concept and the information given in the Construction Documents. Corrections or comments made on the shop drawings during this review do not relieve the contractor from compliance with the requirements of the plans and specifications. Review of a specific item shall not include review of an assembly of which the item is a component. The Contractor is responsible for dimensions to be confirmed and corrected at the jobsite. Information that pertains solely to the fabrication process or to the means, methods, techniques, sequences and procedures of construction, coordination of the Work with that of all other trades and performing all Work in a safe and satisfactory manner.

McFarland-Johnson, Inc.  
 Date: 7-11-07  
 By: Steven J. Dallas

- NOTES:**
- FOR GENERAL NOTES SEE DWG GNI.
  - H2-3 DENOTES MATERIAL SUBJECT TO CHARRY V-NOTCH TEST AT H FREQ. FOR ZONE 2

RECEIVED  
 JUL 16 2007

OUT FOR APPROVAL	7-2-07										
ISSUED TO SHOP											
FIELD & OFFICE											
REV.	REMARKS	DATE	DWN	CHK	APP	Q.A.	NO.	DIA.	LGT	TYPE	WASHER
MATERIAL:	ELECTRODES:	HOLES:	SHOP BOLTS:								
M270 50 U.N.		15/16 U.N.	NONE								
SURFACE PREP. & PAINT:											
DESCRIPTION:	CAMBER & FLANGE DIAGRAM								DRAWN BY:	DATE:	
JOB:	BROOK ROAD OVER FREEMAN BROOK								EEO	05/23/07	
	BIRDGE NO. 7								CHKD BY:		
	WARREN, VT. (COUNTY OF WASHINGTON)								ELC	6/05/07	
PROJ. NO.	BHF 0188(?)								APPROV BY:		
CUSTOMER:	BLOW & COTE								SUPERVISOR	W. J. GATTI	
	CASCO BAY STEEL STRUCTURES, INC.								JOB NO.	DRG. NO.	
	75 SPRING HILL ROAD SACO, MAINE 04072								324	C1	
	PHONE (207) 282-7360 FAX. (207) 282-1179								05055	REV.	