



REVISIONS					
ZONE	REV	DESCRIPTION	REVISED BY	DATE	APPROVED



PLAN VIEW

Vermont Agency of Transportation
RECEIVED
 CK'D BY M. UMBERGER OK'D BY MRU
 April 28, 2014
 RESUBMIT NO Approved
 BY C. CARLSON DATE 06/04/2014



SECTION A-A
 QTY. REQ'D. = 16

Inspection Block
Initial Dim. Check Sign: _____ Date: _____
In Process Dim. Chk. Sign: _____ Date: _____
100% Visual Weld Insp. Sign: _____ Date: _____
Point Insp.(see form) Sign: _____ Date: _____
Final Inspection Sign: _____ Date: _____

- NOTES:**
- MANUFACTURING FACILITY LOCATION:
 AMSCOT STRUCTURAL PRODUCTS CORP.
 241 E. BLACKWELL STREET
 DOVER, N.J. 07801
 CONTACT- PETER SOMOGYI
 PH: 973-989-8800
 FAX: 973-989-5851
 - ALL BEARING PADS TO BE MANUFACTURED IN ACCORDANCE WITH AASHTO SECTION 18. THE ELASTOMER SHALL BE GRADE 3 NEOPRENE WITH A DUROMETER HARDNESS OF 50 ± 5. THE STEEL REINFORCING PLATES SHALL CONFORM TO ASTM A36.
 - THE BEARINGS ARE DESIGNED SO THE SUPERSTRUCTURE MAY BE ERECTED WHEN THE AMBIENT AIR TEMPERATURE IS WITHIN THE RANGE OF 40° F. TO 80° F.
 - ALL DIMENSIONS ARE IN INCHES , UNLESS OTHERWISE NOTED.
 - TOLERANCES: THICKNESS -0 +1/8
 PLAN -0 +1/8

MONTGOMERY
BHO 1448(27)
 STATE OF VERMONT AGENCY OF TRANSPORTATION
 FEDERAL PROJECT NO. :
VTRANS ITEM # 531.17
STEEL REINFORCED ELASTOMERIC
BEARING DETAILS
AMSCOT
 STRUCTURAL PRODUCTS CORP.
 SCALE: N.T.S. APPRVD: DRAWN BY: E.J.G.
 DATE: 4/28/14 BF REVISION: 0
 FOR: A. L. ST. ONGE CONTRACTOR INC.
 DWG NO: ASD14A1R0 SHEET 1 OF 1