



- GENERAL NOTES
- SEE SITE PLAN S-1 FOR BUILDING LOCATION AND BURIED ELECTRICAL CONDUIT LOCATION.
  - CONCRETE SHALL BE 3000 PSI @ 28 DAYS AND SHALL HAVE A MAXIMUM SLUMP OF 4 IN.
  - ALL EXPOSED CONCRETE SHALL BE RUBBED TO A SMOOTH UNIFORM FINISH.
  - ALL FRAMING LUMBER SHALL BE "CONSTRUCTION GRADE WITH  $\gamma$ " = 1500 PSI.
  - ALL BOLTS AND WASHERS FOR FOUNDATION SHALL BE GALVANIZED.
  - DOOR JAMBS AND HEAD SHALL BE METAL COVERED ALL SIDES.

REVISIONS	By	Date

STATE OF VERMONT  
DIVISION OF STATE BUILDINGS  
AGENCY OF ADMINISTRATION  
MONTPELIER, VERMONT

VERMONT HIGHWAY DEPARTMENT  
Standard Salt Storage Building  
Type II

DESIGNED BY: T. J. S.  
DRAWN BY: C. E. H.  
DATE: 10/18/74  
APPROVED BY: [Signature]

DRWG. NO. SH-1