



LOWER LEVEL PLAN - HEATING  
SCALE: 1/4" = 1'-0"

NOTE 5:  
ALL DIMENSIONS TO BE VERIFIED AT THE SITE BY THE CONTRACTOR. ANY DISCREPANCY OR POINTS IN QUESTION MUST BE REFERRED TO THE ARCHITECT FOR A DECISION BEFORE PROCEEDING WITH THE WORK.

THE SUSPENDED UNITS IN THE BASEMENT ARE TO COMPLY WITH THE REQUIREMENTS OF SECTION M-618.0; BWC-81.  
ALL GAS-FIRED EQUIPMENT IS TO COMPLY WITH THE APPLICABLE SECTIONS OF ARTICLE 6; BWC-81 AND 835.

THE BOILER ROOM AND ALL STORAGE AREAS OVER 50 SQUARE FEET IN AREA ARE TO BE EQUIPPED WITH SPRINKLERS OR SOME OTHER FORM OF AUTOMATIC FIRE SUPPRESSION SYSTEM, 1702.16 AND 1702.12; B3C-81.

ALL ASPECTS OF THE BOILER AND ITS INSTALLATION AND ASSOCIATED EQUIPMENT ARE TO BE IN COMPLIANCE WITH THE 1985 VERMONT BOILER AND PRESSURE VESSEL RULES.

NOTE:  
IN THE ALTERNATE PLAN COMBUSTION AIR SHALL BE PROVIDED AS DESCRIBED IN M-610.0; BWC-81 AND 835 (1981 BOCA BASIC MECHANICAL CODE AND ITS 1985 SUPPLEMENT).



**AGENCY OF TRANSPORTATION - NEW OFFICE**  
STATE OF VERMONT DEPT. OF STATE BUILDINGS  
DUMMERSTON, VERMONT  
GORDON G. WOODS ASSOC. ARCHITECTS, BURLINGTON, VERMONT

REVISIONS	BY
B-9-'85	BW
FAHON INDUSTRIES LETTER #24-85	BW
10-2-85	
5-16-86	

DATE	JULY 24, 1985
SCALE	1/4" INCH = 1 FOOT
JOB NO.	8420
SHEET	
DRAWN	DW / JLV
CHECKED	
<b>HI</b>	
27	32 SHEETS