



AIR CONDITIONER SCHEDULE

MAKE/MODEL	CAPACITY @95°	VOLTS	AMPS	MAXIMUM FUSE SIZE	SEER	REMARKS
AC 1 MITSUBISHI PL24AK	24,000 BTU	115/1/60	3.0	15	10.0	
ACC 1 MITSUBISHI PL24EK		230/1/60	16.0	20		MATCHED TO INDOOR UNIT

EQUIPMENT SCHEDULE

PLAN SYMBOL	DESCRIPTION	MANUF. & MODEL	CHARACTERISTICS	ELECTRIC VOLTS/ # /HZ	NOTES
L-1	RELIEF LOUVER VENT PRODUCTS 2750		12"x12"		
MOD-1	RELIEF DAMPER VENT PRODUCTS 5703		12"x12"		BELOW DIRECT COUPLED ACTUATOR
L-2	RELIEF LOUVER VENT PRODUCTS 2740		12"x12"		
MOD-2	RELIEF DAMPER VENT PRODUCTS 5703		12"x12"		BELOW DIRECT COUPLED ACTUATOR
RH-1	REHEAT COIL	McQUAY 5850801H	12x12 EMT 40F UAT 95F 180 EMT 160 LMT 2.4 gpm 24,412 BTU		PROVIDE 3 - WAY CONTROL VALVE

AIR HANDLER SCHEDULE

MAKE/MODEL	CFM	ESP	VOLTS	PHASE	MAXIMUM CIRCUIT CAPACITY	REMARKS	
HX-1	SEWCO RV-500	550	0.9	115	1	15	PROVIDE AN OFF/HIGH/LOW SPEED SWITCH FOR OPERATION. DISCHARGE AIR SENSOR TO MODULATE VALVE TO MAINTAIN DISCHARGE AIR TEMP 65° F (ADD.)

