



NOTE 1:  
1/ SUPPLY REGISTERS ARE ADJUSTABLE DOUBLE DEFLECTOR  
W/ VOLUME DAMPER, ALUMINUM - CARLES MODEL 6821 OR  
EQUAL. FRAME ALUMINUM OR BRASS BRASS VOLUME DAMPER BEHIND EACH REGISTER.  
2/ PROVIDE SPRINGING BEHIND IN ALL DUCT-WALL.  
3/ PROVIDE FILTERS IN ALL RETURN AIR DUCTS.

STATE OF VERMONT DIVISION OF STATE BUILDINGS AGENCY OF ADMINISTRATION MONTPELIER, VERMONT			
WOOD BURNING FURNACE INSTALLATION GARAGE AT MOORESVILLE AGENCY OF TRANSPORTATION			
DATE: 10.5.91	SCALE: AS NOTED	REVISIONS: 5 NOV 91 NR	DWG. NO. OF
DRAWN BY: SL	APPROVED BY:		