3803

INDICATES 37,500 BTUH GAS FIRED INFRA RED HEATING UNIT (PROPANE)

INDICATES 25,000 BTUH GAS FIRED INFRA RED HEATING UNIT (PROPANE)

INDICATES THERMOSTAT HEAVY DUTY 20 AMP. RANGE 40°-75°F

OVER HEAD DOOR FRAME

MECHANICAL

GREASE & OIL

STOCK ROOM

TOILET

OFFICE

ZONE B (20' CLOSET)

ZONE C (20'x 66'9")

OMITTED ON 4 BAY GARAGE

A,B,C,D RELOCATE 4 UNITS

A, E-J CHANGE ANGLE ON 7 UNITS TO 30° FROM HORIZ

PLAN SCALE: 3/16" = 1'-0"

HANGING DIAGRAM HEATERS #2-#11

HANGING DIAGRAM HEATERS #1, #20, & #21

HANGING DIAGRAM HEATERS #15 - #19

HANGING DIAGRAM HEATERS #12 & #13

IMPORTANT

KEEP GAS PIPING, LIGHTS, ETC. AWAY FROM HEAT ZONES

GAS MAIN

TYPICAL PIPING DETAIL

NO SCALE

NOTE

1. NECESSARY VENTILATION BY OTHERS
2. ELECTRICAL CONNECTION TO VENTILATION IS NOT ON THE CONTRACT

HEATER REL. MORRISVILLE

HEATING PLAN

DISTRICT #4 GARAGE

~~WHITE RIVER JUNCTION~~ VERGENNES

DATE Oct 29, 65	STATE BUILDINGS DIV
SCALE AS NOTED	DEPT. OF ADMINISTRATION
	MONTPELIER VERMONT
DRAWING Library	SHEET 5