



PROVIDE ADDITIONAL PVC JACKETING ON EXTERIOR OF EXPOSED HEATING PIPING DROPS, TYPICAL ALL RADIATION

EXISTING 1 HOUR RATED MECHANICAL ROOM WITH 1 HOUR RATED DOOR AND FRAME

SEE COMBUSTION VENTILATION AIR DETAIL, DRAWING M2

WEIL-McLAIN MODEL ULTRA155 LP GAS BOILER WITH WALL MOUNT KIT AND VENT/AIR SIDEWALL TERMINATION

EXISTING TOILET EXHAUST FAN TO REMAIN

500 GALLON UNDERGROUND LP GAS TANK, LOCATED AND INSTALLED BY STATE OF VERMONT

PRIMARY REGULATOR/SHUTOFF FURNISHED AND INSTALLED BY STATE OF VERMONT CONTRACTOR TO CONNECT TO SECONDARY REGULATOR ON BUILDING. SEE DETAILS, DRAWING M5.

FLOOR PLAN - MECHANICAL
SCALE: 1/4"=1'-0"

X:\031226\Drawings\Mech\031226M01.dwg, M1, 12/27/2005, 1:05:56 PM, © LANE ASSOCIATES CONSULTING ENGINEERS P.C. 2005

	2	REVISED FOR BIDDING	12/21/2005
	1	BIDDING	10/20/2005
NO.	ISSUED FOR	DATE	



HEATING, VENTILATION, & AIR CONDITIONING,
PLUMBING, FIRE PROTECTION, & ELECTRICAL

CHARLES F. LANE, P.E.
DANIEL W. DUPRAS, P.E.

51 KILLINGTON AVENUE,
RUTLAND, VERMONT 05701
TELEPHONE: (802)747-3346
FAX/MODEM: (802)747-3356

FLOOR PLAN - MECHANICAL				M 1			
NEW HEATING SYSTEM BRIDGE SHOP/STOCK BUILDING ST. JOHNSBURY AOT ST. JOHNSBURY, VT							
APPR:	DVD	DRAWN:	DVD/GJT	SCALE:	AS NOTED	PROJ. NO.:	0312-26