

PANEL L1-A VOLTAGE 120/208 PHASE 3Ø 4W MAIN 350 A-TRIP CHECK

TYPE PANELBOARD LOADCENTER PLE IN BOLT ON FAULT RATING 10,000

LOCATION W.C. Elec. RM -

Mountings SURFACE

DIRECTORY	TRIP	AMP	BP	CP	TRIP	DIRECTORY
Venue Machines	20	3			2	20 Stg & Repair BGRM
	20	1			4	20 Bk. RM EITRON, M. HALL
	20	5			6	20 " " COUNTER
	20	7			8	20 CASH, OFFICE, M. HALL
	20	9			10	20 MAIN HALL & OFFICE EST.
	20	11			12	20 2Y Hk Kiosk
	20	13			14	20 FARM RECEPT WEST
	20	15			16	20 " " "
	20	17			18	20 RECEPT TRUCK 2YHk
	20	19			20	20 TRUCK GFI
	20	21			22	20 RECEPT WAREHOUSE ENTRY
	20	23			24	20 FARM RECEPT EAST

CONNECTED LOAD DEMAND

NOTES

PANEL L1-B VOLTAGE 120/208 PHASE 3Ø 4W MAIN 350 A-TRIP CHECK

TYPE PANELBOARD LOADCENTER PLE IN BOLT ON FAULT RATING 10,000

LOCATION W.C. Elec. RM -

Mountings SURFACE

DIRECTORY	TRIP	AMP	BP	CP	TRIP	DIRECTORY
TRUCK LITS	20	4			20	FARM RECEPT EAST
2Y Hk & VEST. LITS	20	2			20	EXTERNAL RECEPT
PATIO LIGHTS	20	24			20	CANAL SINK LIT'S RECEPT
DAMP SINKION ALUMIN	20	3			20	" " " "
DAMP SINK LIT'S RECEPT	20	3			20	" " " "
INTD CAB LITS	20	4			20	REMOVAL CHILLER
INTD CAB RECEPT	20	3			20	ELEC RM. EX FAN
SPACE	20	3			20	SPACE
SPACE	20	4			20	SPACE

CONNECTED LOAD DEMAND

NOTES

PANEL M8PL VOLTAGE 120/240 PHASE 1 MAIN 60 A-TRIP CHECK

TYPE PANELBOARD LOADCENTER PLE IN BOLT ON FAULT RATING 10,000

LOCATION MAINT. BLDG -

Mountings SURFACE

12 CKT

DIRECTORY	TRIP	AMP	BP	CP	TRIP	DIRECTORY
SPACE ONLY	1				2	20 QUAD RECEPT
SPACE ONLY	3				4	20 " " "
SPACE ONLY	20				6	20 GARAGE DOOR
SPACE	20				8	20 " " "
MAIN	60				10	20 BUILDING LIGHTS
	60				12	20 LIGHTS
	15				14	20 " " "
	15				16	20 " " "
	11				18	20 " " "
	14				20	20 " " "
	21				22	20 " " "
	25				24	20 " " "
	25				26	20 " " "
	27				28	20 " " "
	29				30	20 " " "
	31				32	20 " " "
	33				34	20 " " "
	35				36	20 " " "
	31				38	20 " " "
	34				40	20 " " "
	41				42	20 " " "

CONNECTED LOAD DEMAND

NOTES

RECORD
DRAWING

NO. DATE REVISIONS DRAWN CHECK

TIMOTHY D. SEETH & ASSOCIATES
OLD RAILROAD STATION
802-442-8181

WRIGHT ENGINEERING, LTD.
CIVIL ENGINEERS
128 HERRINGTONS RD - P.O. BOX 176
BURLINGTON, VERMONT 05402-0176
902-776-8811

ROBT W. HALL
CONSULTING ENGINEERS, INC.
540 MADISON STREET EXTENSION, STE. 2
ACQUINA, MASSACHUSETTS 01001-0002
413-789-0900

STATE OF VERMONT
AGENCY OF ADMINISTRATION
DEPARTMENT OF
BUILDINGS & GENERAL SERVICES

SHEET TITLE: ELECTRICAL PANEL CLARIFICATION

GUILFORD, VERMONT

DESIGN BY: _____
DRAWN BY: _____
CHECK BY: _____

DATE: 3-14-2000 SHEET NO. _____ OF _____ SHEETS

AB
15