


**NOTES:**

1. THERMOSTAT TO BE FURNISHED BY MECHANICAL CONTRACTOR AND INSTALLED BY ELECTRICAL CONTRACTOR AT LOCATION SHOWN. REFER TO THERMOSTAT/AQUASTAT CONTROL DIAGRAM ON DRAWING E-7 FOR MORE DETAIL. TYPICAL FOR ALL THERMOSTATS SHOWN FOR ALL UNIT HEATERS THROUGHOUT BUILDING. THERMOSTAT TO BE INSTALLED ON UNSUPPORTED MOUNTED TO FLOOR JOIST ABOVE SO THERMOSTAT IS 8" BELOW BOTTOM OF FLOOR JOIST.
2. MECHANICAL CONTRACTOR TO FURNISH AND INSTALL UNIT HEATER AND AQUASTAT MOUNTED TO HOT WATER PIPING. ELECTRICAL CONTRACTOR TO WIRE TO UNIT HEATER AND AQUASTAT AS SHOWN ON THERMOSTAT/AQUASTAT CONTROL DIAGRAM ON DRAWING E-7. TYPICAL FOR ALL UNIT HEATERS SHOWN THROUGHOUT BUILDING.
3. HUMIDISTAT TO BE FURNISHED BY MECHANICAL CONTRACTOR AND INSTALLED BY ELECTRICAL CONTRACTOR AT LOCATION SHOWN. REFER TO HUMIDISTAT CONTROL DIAGRAM ON DRAWING E-7 FOR MORE DETAIL.
4. FURNISH AND INSTALL JUNCTION BOX FOR CONTROL POWER FOR MECHANICAL EQUIPMENT.
5. FURNISH AND INSTALL (2) ERG-CAT 32 1-HOOKS MOUNTED TO FLOOR JOISTS FOR COMMUNICATIONS CABLE MANAGEMENT. REFER TO CABLE MANAGEMENT DETAIL ON DRAWING E-7.



No.	DATE	REVISION

**DUNCAN • WISNIEWSKI ARCHITECTURE**  
256 SOUTH CHAMPLAIN STREET, BURLINGTON, VERMONT 05401 (802) 864-8893

**Hallam Associates**  
60 Farrell Street, Suite 300  
So. Burlington, Vermont 05403  
(802) 658-4891

**WILLISTON INFORMATION CENTER**  
189 SOUTHBOUND  
STATE PROJECT # IM-BLDG (4)

**CRAWL SPACE LTG AND POWER PLAN**

DRAWN: CS  
CHECKED: BPP  
PROLOG: 10215  
DATE: JAN 16, 2001

**E-2sb**