

NOTE
 A concrete pad of sufficient size for at least a 50 KVA pad-mount transformer will be supplied by the contractor. 3" PVC conduit sweep bends, through the concrete pad will be installed by the contractor. For location of the pad and for dimension details, the contractor will contact Vermont Electric Co-op - 58 Lane.

REMOVAL AND DISPOSAL OF EXISTING
 GUARD RAIL ITEM 202.40
 NB RT. 448
 NB LT. 448

GUARD RAIL, THREE CABLE WITH
 LIGHT WOOD POSTS ITEM 621
 NB RT. 448 W/2 ANCHORS
 NB LT. 448 W/2 ANCHORS



NORTHBOUND REST AREA
 SUBMITTED BY _____ DATE _____
 DRAWN BY _____ DATE 12/20/71
 TRACED BY RCW
 GEORGIA - FAIRFAX
 PROJ. I NO. 59-31501
 SHEET 4 OF 35

SCALE 1" = 20'